


INVITATION TO BID STATE OF LOUISIANA DIVISION OF ADMINISTRATION OFFICE OF STATE PURCHASING				BIDS WILL BE PUBLICLY OPENED: <div style="font-size: 1.2em; font-weight: bold;">FEB 25, 2010 10:00 AM</div>	
=====> VENDOR NO. : SOLICITATION : 2238331 FILE NO. : OPENING DATE : 02/25/10 <div style="border: 1px solid black; height: 80px; width: 100%; margin-top: 10px;"></div>		PURCHASING AGENCY NO. : 107001 SEE NO. 8 BELOW. RETURN BID TO <div style="text-align: right;">10:00 AM</div> <div style="display: flex; justify-content: space-between;"> 2238331 02/25/10 </div> OFFICE OF STATE PURCHASING OFFICE OF STATE PURCHASING POST OFFICE BOX 94095 BATON ROUGE, LA 70804-9095 <div style="display: flex; justify-content: space-between;"> <div> BUYER : ROB HAYNES BUYER PHONE : (225) 342-8035 DATE ISSUED : 01/26/10 REQ. AGENCY : 107001 </div> <div style="text-align: right;">FOLD HERE--></div> </div> OFFICE OF STATE PURCHASING AGENCY REQ. NO. : ISIS REQ. NO. : 1329946 VENDOR PHONE : FISCAL YEAR : 10 CLASS/SUBCLASS : 28539 SCHEDULED BEGIN DATE : 04/01/10 SCHEDULED END DATE : 03/31/11 T-NUMBER : 92084			
<div style="border: 1px solid black; width: 100%; height: 80px; margin: 0 auto;"></div> <p style="font-weight: bold; margin-top: 10px;">FILL IN VENDOR NUMBER (FEIN), NAME AND ADDRESS ABOVE, BEFORE SUBMITTING BID.</p>					
<i>GENERATORS, STATIONARY AND TOWABLE STATEWIDE CONTRACT</i>					
TO BE COMPLETED BY VENDOR					
1. _____ PLEASE REMOVE FROM THIS COMMODITY CODE. 2. _____ DELIVERY WILL BE MADE IN THIS NUMBER OF DAYS AFTER RECEIPT OF ORDER. 3. _____ % CASH DISCOUNT FOR PROMPT PAYMENT IF MADE WITHIN THIRTY (30) DAYS. CASH DISCOUNTS FOR LESS THAN 30 DAYS OR LESS THAN 1% WILL BE ACCEPTED, BUT WILL NOT BE CONSIDERED IN DETERMINING AWARDS. ON INDEFINITE QUANTITY TERM CONTRACTS, CASH DISCOUNTS WILL BE ACCEPTED AND TAKEN BUT WILL NOT BE CONSIDERED IN DETERMINING AWARDS. 4. _____ BID BOND ATTACHED, _____ CERTIFIED CHECK ATTACHED, _____ OTHER, IF REQUIRED. 5. _____ BID REFERENCE NUMBER. (THIS NUMBER WILL APPEAR ON RESULTING ORDER OR CONTRACT).					
INSTRUCTIONS TO BIDDERS					
1. READ THE ENTIRE BID, INCLUDING ALL TERMS AND CONDITIONS AND SPECIFICATIONS. 2. ALL BID PRICES MUST BE TYPED OR WRITTEN IN INK. ANY CORRECTIONS, ERASURES OR OTHER FORMS OF ALTERATION TO UNIT PRICES SHOULD BE INITIALED BY THE BIDDER. 3. THIS BID IS TO BE MANUALLY SIGNED IN INK. FOLD HERE--> 4. BID PRICES SHALL INCLUDE DELIVERY OF ALL ITEMS F.O.B. DESTINATION OR AS OTHERWISE PROVIDED. BIDS CONTAINING "PAYMENT IN ADVANCE" OR "C.O.D" REQUIREMENTS MAY BE REJECTED. PAYMENT IS TO BE MADE WITHIN 30 DAYS AFTER RECEIPT OF PROPERLY EXECUTED INVOICE OR DELIVERY, WHICHEVER IS LATER. 5. AMOUNT OF BID BOND REQUIRED: _____ N/A _____ . 6. AMOUNT OF PERFORMANCE BOND, IF REQUIRED. _____ OR _____ 0% _____ OF BID. 7. DESIRED DELIVERY: _____ 060DAYS ARO 8. TO ASSURE CONSIDERATION OF YOUR BID, ALL BIDS AND ADDENDA SHOULD BE RETURNED IN AN ENVELOPE OR PACKAGE CLEARLY MARKED WITH THE BID OPENING DATE AND THE BID NUMBER, OR SUBMITTED IN THE SPECIAL ENVELOPE IF FURNISHED FOR THAT PURPOSE. 9. BIDS SUBMITTED ARE SUBJECT TO PROVISIONS OF THE LAWS OF THE STATE OF LOUISIANA INCLUDING BUT NOT LIMITED TO L.R.S. 39:1551-1736; PURCHASING RULES AND REGULATIONS; EXECUTIVE ORDERS; STANDARD TERMS AND CONDITIONS; SPECIAL CONDITIONS; AND SPECIFICATIONS LISTED IN THIS SOLICITATION. 10. IMPORTANT: BY SIGNING THE BID, THE BIDDER CERTIFIES COMPLIANCE WITH ALL INSTRUCTIONS TO BIDDERS, TERMS, CONDITIONS AND SPECIFICATIONS, AND FURTHER CERTIFIES THAT THIS BID IS MADE WITHOUT COLLUSION OR FRAUD. THIS BID IS TO BE MANUALLY SIGNED IN INK BY A PERSON AUTHORIZED TO BIND THE VENDOR (SEE NO.30). ALL BID INFORMATION SHALL BE MADE WITH INK OR TYPEWRITTEN.					
VENDOR PHONE NUMBER: FAX NUMBER:		TITLE		DATE	
SIGNATURE OF AUTHORIZED BIDDER - SEE NO. 30, PAGE 3. (MUST BE SIGNED)			NAME OF BIDDER (TYPED OR PRINTED)		

STANDARD TERMS & CONDITIONS		INVITATION TO BID	
NUMBER : 2238331 OPEN DATE: 02/25/10 TIME: 10:00 AM T-NUMBER : 92084		BIDDER:	PAGE 2
<p>11 ADDRESS ALL INQUIRIES AND CORRESPONDENCE TO THE BUYER AT THE PHONE AND ADDRESS SHOWN ABOVE.</p> <p>12. CONFERENCE: NA NA NA</p> <p>13. BID FORMS. ALL WRITTEN BIDS, UNLESS OTHERWISE PROVIDED FOR, MUST BE SUBMITTED ON, AND IN ACCORDANCE WITH, FORMS PROVIDED, PROPERLY SIGNED (SEE NO. 30). BIDS SUBMITTED IN THE FOLLOWING MANNER WILL NOT BE ACCEPTED:</p> <ul style="list-style-type: none">A. BID CONTAINS NO SIGNATURE INDICATING INTENT TO BE BOUND;B. BID FILLED OUT IN PENCIL; ANDC. BID NOT SUBMITTED ON THE STATE'S STANDARD FORMS. <p>BIDS MUST BE RECEIVED AT THE ADDRESS SPECIFIED IN THE SOLICITATION PRIOR TO BID OPENING TIME IN ORDER TO BE CONSIDERED. TELEGRAPHIC AND FAX ALTERATIONS TO BIDS RECEIVED BEFORE BID OPENING TIME WILL BE CONSIDERED PROVIDED FORMAL BID AND WRITTEN ALTERATION HAVE BEEN RECEIVED AND TIME-STAMPED BEFORE BID OPENING TIME. ENTIRE BID SHOULD BE RETURNED, EXCEPT ITEM PAGES NOT BID.</p> <p>14. STANDARDS OF QUALITY. ANY PRODUCT OR SERVICE BID SHALL CONFORM TO ALL APPLICABLE FEDERAL AND STATE LAWS AND REGULATIONS AND THE SPECIFICATIONS CONTAINED IN THE SOLICITATION. UNLESS OTHERWISE SPECIFIED IN THE SOLICITATION, ANY MANUFACTURER'S NAME, TRADE NAME, BRAND NAME, OR CATALOG NUMBER USED IN THE SPECIFICATION IS FOR THE PURPOSE OF DESCRIBING THE STANDARD OF QUALITY, PERFORMANCE, AND CHARACTERISTICS DESIRED AND IS NOT INTENDED TO LIMIT OR RESTRICT COMPETITION. BIDDER MUST SPECIFY THE BRAND AND MODEL NUMBER OF THE PRODUCT OFFERED IN HIS BID. BIDS NOT SPECIFYING BRAND AND MODEL NUMBER SHALL BE CONSIDERED AS OFFERING THE EXACT PRODUCTS SPECIFIED IN THE SOLICITATION.</p> <p>15. DESCRIPTIVE INFORMATION. BIDDERS PROPOSING AN EQUIVALENT BRAND OR MODEL SHOULD SUBMIT WITH THE BID INFORMATION (SUCH AS ILLUSTRATIONS, DESCRIPTIVE LITERATURE, TECHNICAL DATA) SUFFICIENT FOR STATE OF LOUISIANA TO EVALUATE QUALITY, SUITABILITY, AND COMPLIANCE WITH THE SPECIFICATIONS IN THE SOLICITATION. FAILURE TO SUBMIT DESCRIPTIVE INFORMATION MAY CAUSE BID TO BE REJECTED. ANY CHANGE MADE TO A MANUFACTURER'S PUBLISHED SPECIFICATIONS SUBMITTED FOR A PRODUCT SHALL BE VERIFIABLE BY THE MANUFACTURER. IF ITEM(S) BID DO NOT FULLY COMPLY WITH SPECIFICATIONS (INCLUDING BRAND AND/OR PRODUCT NUMBER), BIDDER MUST STATE IN WHAT RESPECT ITEM(S) DEVIATE. FAILURE TO NOTE EXCEPTIONS ON THE BID FORM WILL NOT RELIEVE THE SUCCESSFUL BIDDER(S) FROM SUPPLYING THE ACTUAL PRODUCTS REQUESTED.</p> <p>16. BID OPENING. BIDDERS MAY ATTEND THE BID OPENING, BUT NO INFORMATION OR OPINIONS CONCERNING THE ULTIMATE CONTRACT AWARD WILL BE GIVEN AT THE BID OPENING OR DURING THE EVALUATION PROCESS. BIDS MAY BE EXAMINED WITHIN 72 HOURS AFTER BID OPENING. INFORMATION PERTAINING TO COMPLETED FILES MAY BE SECURED BY VISITING THE STATE OF LOUISIANA DURING NORMAL WORKING HOURS. WRITTEN BID TABULATIONS WILL NOT BE FURNISHED.</p> <p>17. AWARDS. THE STATE OF LOUISIANA RESERVES THE RIGHT TO AWARD ITEMS SEPARATELY, GROUPED OR ON AN ALL-OR-NONE BASIS AND TO REJECT ANY OR ALL BIDS AND WAIVE ANY INFORMALITIES.</p> <p>18. PRICES . UNLESS OTHERWISE SPECIFIED BY THE STATE OF LOUISIANA IN THE SOLICITATION, BID PRICES MUST BE COMPLETE, INCLUDING TRANSPORTATION PREPAID BY BIDDER TO DESTINATION AND FIRM FOR ACCEPTANCE FOR A MINIMUM OF 30 DAYS. IF ACCEPTED, PRICES MUST BE FIRM FOR THE CONTRACTUAL PERIOD. BIDS OTHER THAN F.O.B. DESTINATION MAY BE REJECTED. PRICES SHOULD BE QUOTED IN THE UNIT (EACH, BOX, CASE, ETC.) AS SPECIFIED IN THE SOLICITATION.</p> <p>19. DELIVERIES. BIDS MAY BE REJECTED IF THE DELIVERY TIME INDICATED IS LONGER THAN THAT SPECIFIED IN THE SOLICITATION.</p> <p>20. TAXES. VENDOR IS RESPONSIBLE FOR INCLUDING ALL APPLICABLE TAXES IN THE BID PRICE. STATE AGENCIES ARE EXEMPT FROM ALL STATE AND LOCAL SALES AND USE TAXES.</p>			

STANDARD TERMS & CONDITIONS		INVITATION TO BID	
NUMBER : 2238331 OPEN DATE: 02/25/10 TIME: 10:00 AM T-NUMBER : 92084		BIDDER:	PAGE 3
<p>21. NEW PRODUCTS.</p> <p>UNLESS SPECIFICALLY CALLED FOR IN THE SOLICITATION, ALL PRODUCTS FOR PURCHASE MUST BE NEW, NEVER PREVIOUSLY USED, AND THE CURRENT MODEL AND/OR PACKAGING. NO REMANUFACTURED, DEMONSTRATOR, USED OR IRREGULAR PRODUCT WILL BE CONSIDERED FOR PURCHASE UNLESS OTHERWISE SPECIFIED IN THE SOLICITATION. THE MANUFACTURER'S STANDARD WARRANTY WILL APPLY UNLESS OTHERWISE SPECIFIED IN THE SOLICITATION.</p> <p>22. CONTRACT RENEWALS.</p> <p>UPON AGREEMENT OF THE STATE OF LOUISIANA AGENCY AND THE CONTRACTOR, A TERM CONTRACT MAY BE EXTENDED FOR 2 ADDITIONAL 12-MONTH PERIODS AT THE SAME PRICES, TERMS AND CONDITIONS. IN SUCH CASES, THE TOTAL CONTRACT TERM CANNOT EXCEED 36 MONTHS.</p> <p>23. CONTRACT CANCELLATION.</p> <p>THE STATE OF LOUISIANA HAS THE RIGHT TO CANCEL ANY CONTRACT, IN ACCORDANCE WITH PURCHASING RULES AND REGULATIONS, FOR CAUSE, INCLUDING BUT NOT LIMITED TO, THE FOLLOWING: (1) FAILURE TO DELIVER WITHIN THE TIME SPECIFIED IN THE CONTRACT; (2) FAILURE OF THE PRODUCT OR SERVICE TO MEET SPECIFICATIONS, CONFORM TO SAMPLE QUALITY OR TO BE DELIVERED IN GOOD CONDITION; (3) MISREPRESENTATION BY THE CONTRACTOR; (4) FRAUD, COLLUSION, CONSPIRACY OR OTHER UNLAWFUL MEANS OF OBTAINING ANY CONTRACT WITH THE STATE; (5) CONFLICT OF CONTRACT PROVISIONS WITH CONSTITUTIONAL OR STATUTORY PROVISIONS OF STATE OR FEDERAL LAW; (6) ANY OTHER BREACH OF CONTRACT.</p> <p>24. DEFAULT OF CONTRACTOR.</p> <p>FAILURE TO DELIVER WITHIN THE TIME SPECIFIED IN THE BID WILL CONSTITUTE A DEFAULT AND MAY CAUSE CANCELLATION OF THE CONTRACT. WHERE THE STATE HAS DETERMINED THE CONTRACTOR TO BE IN DEFAULT, THE STATE RESERVES THE RIGHT TO PURCHASE ANY OR ALL PRODUCTS OR SERVICES COVERED BY THE CONTRACT ON THE OPEN MARKET AND TO CHARGE THE CONTRACTOR WITH COST IN EXCESS OF THE CONTRACT PRICE. UNTIL SUCH ASSESSED CHARGES HAVE BEEN PAID, NO SUBSEQUENT BID FROM THE DEFAULTING CONTRACTOR WILL BE CONSIDERED.</p> <p>25. ORDER OF PRIORITY.</p> <p>IN THE EVENT THERE IS A CONFLICT BETWEEN THE INSTRUCTIONS TO BIDDERS OR STANDARD CONDITIONS AND THE SPECIAL CONDITIONS, THE SPECIAL CONDITIONS SHALL GOVERN.</p> <p>26. APPLICABLE LAW.</p> <p>ALL CONTRACTS SHALL BE CONSTRUED IN ACCORDANCE WITH AND GOVERNED BY THE LAWS OF THE STATE OF LOUISIANA.</p> <p>27. COMPLIANCE WITH CIVIL RIGHTS LAWS.</p> <p>BY SUBMITTING AND SIGNING THIS BID, BIDDER AGREES TO ABIDE BY THE REQUIREMENTS OF THE FOLLOWING AS APPLICABLE: TITLE VI AND VII OF THE CIVIL RIGHTS ACT OF 1964, AS AMENDED BY THE EQUAL OPPORTUNITY ACT OF 1972, FEDERAL EXECUTIVE ORDER 11246, FEDERAL REHABILITATION ACT OF 1973, AS AMENDED, THE VETERAN'S READJUSTMENT ASSISTANCE ACT OF 1974, TITLE IX OF THE EDUCATION AMENDMENTS OF 1972, THE AGE ACT OF 1975, AND BIDDER AGREES TO ABIDE BY THE REQUIREMENTS OF THE AMERICANS WITH DISABILITIES ACT OF 1990. BIDDER AGREES NOT TO DISCRIMINATE IN ITS EMPLOYMENT PRACTICES, AND WILL RENDER SERVICES UNDER ANY CONTRACT ENTERED INTO AS A RESULT OF THIS SOLICITATION WITHOUT REGARD TO RACE, COLOR, RELIGION, SEXUAL ORIENTATION, NATIONAL ORIGIN, VETERAN STATUS, POLITICAL AFFILIATION, OR DISABILITIES. ANY ACT OF DISCRIMINATION COMMITTED BY BIDDER, OR FAILURE TO COMPLY WITH THESE STATUTORY OBLIGATIONS WHEN APPLICABLE, SHALL BE GROUNDS FOR TERMINATION OF ANY CONTRACT ENTERED INTO AS A RESULT OF THIS SOLICITATION.</p> <p>28. SPECIAL ACCOMMODATION.</p> <p>ANY "QUALIFIED INDIVIDUAL WITH A DISABILITY" AS DEFINED BY THE AMERICANS WITH DISABILITIES ACT WHO HAS SUBMITTED A BID AND DESIRES TO ATTEND THE BID OPENING, MUST NOTIFY THIS OFFICE IN WRITING NOT LATER THAN SEVEN DAYS PRIOR TO THE BID OPENING DATE OF THEIR NEED FOR SPECIAL ACCOMMODATIONS. IF THE REQUEST CANNOT BE REASONABLY PROVIDED, THE INDIVIDUAL WILL BE INFORMED PRIOR TO THE BID OPENING.</p> <p>29. INDEMNITY.</p> <p>CONTRACTOR AGREES, UPON RECEIPT OF WRITTEN NOTICE OF A CLAIM OR ACTION, TO DEFEND THE CLAIM OR ACTION, OR TAKE OTHER APPROPRIATE MEASURE, TO INDEMNIFY, AND HOLD HARMLESS, THE STATE, ITS OFFICERS, ITS AGENTS AND ITS EMPLOYEES FROM AND AGAINST ALL CLAIMS AND ACTIONS FOR BODILY INJURY, DEATH OR PROPERTY DAMAGES CAUSED BY THE FAULT OF THE CONTRACTOR, ITS OFFICERS, ITS AGENTS, OR ITS EMPLOYEES. CONTRACTOR IS OBLIGATED TO INDEMNIFY ONLY TO THE EXTENT OF THE FAULT OF THE CONTRACTOR, ITS OFFICERS, ITS AGENTS, OR ITS EMPLOYEES. HOWEVER, THE CONTRACTOR SHALL HAVE NO OBLIGATION AS SET FORTH ABOVE WITH RESPECT TO ANY CLAIM OR ACTION FROM BODILY INJURY, DEATH OR PROPERTY DAMAGES ARISING OUT OF THE FAULT OF THE STATE, ITS OFFICERS, ITS AGENTS OR ITS EMPLOYEES.</p> <p>30. SIGNATURE AUTHORITY.</p> <p>IN ACCORDANCE WITH L.R.S. 39:1594 (ACT 121), THE PERSON SIGNING THE BID MUST BE:</p> <ol style="list-style-type: none"> 1. A CURRENT CORPORATE OFFICER, PARTNERSHIP MEMBER OR OTHER INDIVIDUAL SPECIFICALLY AUTHORIZED TO SUBMIT A BID AS REFLECTED IN THE APPROPRIATE RECORDS ON FILE WITH THE SECRETARY OF STATE; OR 2. AN INDIVIDUAL AUTHORIZED TO BIND THE VENDOR AS REFLECTED BY A CORPORATE RESOLUTION, CERTIFICATE OR AFFIDAVIT; OR 3. OTHER DOCUMENTS INDICATING AUTHORITY WHICH ARE ACCEPTABLE TO THE PUBLIC ENTITY. 			

SPECIAL TERMS & CONDITIONS		INVITATION TO BID	
NUMBER : 2238331 OPEN DATE: 02/25/10 T-NUMBER : 92084	TIME: 10:00 AM	BIDDER:	PAGE 4

1 BID DELIVERY INSTRUCTIONS FOR STATE PURCHASING:

BIDDERS ARE HEREBY ADVISED THAT THE U.S. POSTAL SERVICE DOES NOT MAKE DELIVERIES TO OUR PHYSICAL LOCATION.

BIDS MAY BE MAILED THROUGH THE U.S. POSTAL SERVICE TO OUR BOX AT:
OFFICE OF STATE PURCHASING
P O BOX 94095
BATON ROUGE LA 70804-9095

BIDS MAY BE DELIVERED BY HAND OR COURIER SERVICE TO OUR PHYSICAL LOCATION AS FOLLOWS:

OFFICE OF STATE PURCHASING
CLAIBORNE BUILDING, SUITE 2-160
1201 NORTH THIRD STREET
BATON ROUGE, LA 70802

BIDDER IS SOLELY RESPONSIBLE FOR ENSURING THAT ITS COURIER SERVICE PROVIDER MAKES INSIDE DELIVERIES TO OUR PHYSICAL LOCATION. THE OFFICE OF STATE PURCHASING IS NOT RESPONSIBLE FOR ANY DELAYS CAUSED BY THE BIDDER'S CHOSEN MEANS OF BID DELIVERY.

BIDDER IS SOLELY RESPONSIBLE FOR THE TIMELY DELIVERY OF ITS BID. FAILURE TO MEET THE BID OPENING DATE & TIME SHALL RESULT IN REJECTION OF THE BID.

PUBLICIZING AWARDS. IN ACCORDANCE WITH L.A.C.34:I.535, UNSUCCESSFUL BIDDERS WILL BE NOTIFIED OF THE AWARD PROVIDED THAT THEY SUBMIT WITH THEIR BID A SELF-ADDRESSED STAMPED ENVELOPE REQUESTING THIS INFORMATION.

ATTENTION:

RECEIPT OF A SOLICITATION OR AWARD CANNOT BE RELIED UPON AS AN ASSURANCE OF RECEIVING FUTURE SOLICITATIONS. IN ORDER TO RECEIVE FUTURE SOLICITATIONS/AWARDS FROM THIS OFFICE, YOU MUST ENROLL IN THE PROPER CATEGORY ON LAPAC AT THE FOLLOWING WEB SITE:
[HTTP://WWWPRD.DOA.LOUISIANA.GOV/OSP/LAPAC/PUBMAIN.ASP](http://wwwprd.doa.louisiana.gov/osp/lapac/pubmain.asp)
ENROLLMENT IN LAPAC IS FREE AND PROVIDES EMAIL NOTIFICATION OF BID OPPORTUNITIES BASED UPON COMMODITIES THAT YOU SELECT.

2 ***** TERM CONTRACT GENERAL CONDITIONS *****

2. VENDOR'S FORMS. THE PURCHASE/RELEASE ORDER IS THE ONLY BINDING DOCUMENT TO BE ISSUED AGAINST THIS CONTRACT. SIGNING OF VENDOR'S FORMS IS NOT ALLOWED.

3. SUBSTITUTES. ONLY BRANDS AND NUMBERS STATED IN THE AWARD ARE APPROVED FOR DELIVERY UNDER THIS CONTRACT AND ANY SUBSTITUTION MUST RECEIVE PRIOR WRITTEN APPROVAL OF THE DIRECTOR OF STATE PURCHASING OR DESIGNEE.

SPECIAL TERMS & CONDITIONS		INVITATION TO BID	
NUMBER : 2238331 OPEN DATE: 02/25/10 TIME: 10:00 AM T-NUMBER : 92084		BIDDER:	PAGE 5

4. PRICE REDUCTIONS. WHENEVER THERE IS A REDUCTION IN PRICE, WHICH IS LOWER THAN THE CONTRACT PRICE, OFFERED TO SIMILARLY SITUATED CUSTOMERS CONTRACTING FOR THE SAME PERIOD AND UNDER THE SAME TERMS AND CONDITIONS, SAID REDUCTION MUST BE PRESENTED DIRECTLY TO THE DIRECTOR OF STATE PURCHASING. NO PRICE REDUCTION ON A STATEWIDE CONTRACT MAY BE OFFERED TO AN AGENCY UNLESS THAT REDUCTION IS OFFERED TO ALL AGENCIES.

5. DELIVERIES. CONTRACTORS WILL MAINTAIN AN ADEQUATE SUPPLY OF ALL ITEMS IN ORDER TO MEET SPECIFIED DELIVERY.

6. INVOICES. INVOICES WILL BE SUBMITTED BY THE CONTRACTOR TO THE USING AGENCY AND THE INVOICE SHALL REFER TO THE DELIVERY TICKET NUMBER, DELIVERY DATE, PURCHASE/RELEASE ORDER NUMBER. QUANTITY, UNIT PRICE, AND DELIVERY POINT. A SEPARATE INVOICE FOR EACH ORDER DELIVERED AND ACCEPTED SHALL BE SUBMITTED BY THE CONTRACTOR IN DUPLICATE DIRECTLY TO THE ACCOUNTING DEPARTMENT OF THE USING AGENCY. INVOICES SHALL SHOW THE AMOUNT OF ANY CASH DISCOUNT AND SHALL BE SUBMITTED ON THE CONTRACTOR'S OWN INVOICE FORM.

7. PAYMENT. PAYMENT WILL BE MADE ON THE BASIS OF UNIT PRICE AS LISTED IN THIS CONTRACT; SUCH PRICE AND PAYMENT WILL CONSTITUTE FULL COMPENSATION OF FURNISHING AND DELIVERING THE CONTRACT COMMODITIES. IN NO CASE WILL THE STATE AGENCY REFUSE TO MAKE PARTIAL PAYMENTS TO THE CONTRACTOR ALTHOUGH ALL ITEMS HAVE NOT BEEN DELIVERED. THIS PAYMENT IN NO WAY RELIEVES THE CONTRACTOR OF HIS RESPONSIBILITY TO EFFECT SHIPMENT OF THE BALANCE OF THE ORDER. PAYMENT WILL BE TO VENDOR AND ADDRESS AS SHOWN ON ORDER.

8. VENDOR LIST. THE BIDDER WHO SIGNS THE BID WILL BE DESIGNATED AS PRIME CONTRACTOR ON ANY CONTRACT RESULTING FROM THIS SOLICITATION. IF ADDITIONAL DISTRIBUTOR VENDORS ARE AUTHORIZED TO RECEIVE ORDERS FOR ITEMS CONTAINED IN SAID CONTRACT, THE BIDDER MUST SUBMIT WITH THE BID, A LIST OF THOSE ADDITIONAL AUTHORIZED DISTRIBUTORS INCLUDING THE COMPLETE BUSINESS ADDRESS. THE PRIME CONTRACTOR WILL BE RESPONSIBLE FOR THE ACTIONS OF ANY DISTRIBUTOR VENDORS LISTED.

9. COMPLIANCE WITH CIVIL RIGHTS LAWS. BY SUBMITTING AND SIGNING THIS SOLICITATION, THE BIDDER AGREES TO ABIDE BY THE REQUIREMENTS OF THE FOLLOWING AS APPLICABLE: TITLE VI AND TITLE VII OF THE CIVIL RIGHTS ACT OF 1964, AS AMENDED BY THE EQUAL OPPORTUNITY ACT OF 1972, FEDERAL EXECUTIVE ORDER 11246, THE FEDERAL REHABILITATION ACT OF 1973, AS AMENDED, THE VIETNAM ERA VETERAN'S READJUSTMENT ASSISTANCE ACT OF 1974, TITLE IX OF THE EDUCATION AMENDMENTS OF 1972, THE AGE ACT OF 1975, AND BIDDER AGREES TO ABIDE BY THE REQUIREMENTS OF THE AMERICANS WITH DISABILITIES ACT OF 1990. BIDDER AGREES NOT TO DISCRIMINATE IN ITS EMPLOYMENT PRACTICES, AND WILL RENDER SERVICES UNDER ANY CONTRACT ENTERED INTO AS A RESULT OF THIS SOLICITATION, WITHOUT REGARD TO RACE, COLOR, RELIGION, SEX, NATIONAL ORIGIN, VETERAN STATUS, POLITICAL AFFILIATION, OR DISABILITIES. ANY ACT OF DISCRIMINATION COMMITTED BY BIDDER, OR FAILURE TO COMPLY WITH THESE STATUTORY OBLIGATIONS WHEN APPLICABLE, SHALL BE GROUNDS FOR TERMINATION OF ANY CONTRACT ENTERED INTO AS A RESULT OF THIS SOLICITATION.

10. COOPERATIVE PURCHASE. POLITICAL SUBDIVISIONS OF THE STATE, QUASI

SPECIAL TERMS & CONDITIONS		INVITATION TO BID	
NUMBER : 2238331 OPEN DATE: 02/25/10 TIME: 10:00 AM T-NUMBER : 92084		BIDDER:	PAGE 6

STATE AGENCIES, AND EXTERNAL PROCUREMENT UNITS (DESCRIBED BELOW), MAY BE PERMITTED TO PURCHASE FROM CONTRACTS MADE BY THE OFFICE OF STATE PURCHASING. THE BIDDER MAY, AT ITS OPTION, PERMIT POLITICAL SUB-DIVISIONS OF THE STATE, QUASI STATE AGENCIES, AND EXTERNAL PROCUREMENT UNITS TO PURCHASE FROM ANY CONTRACTS AWARDED AGAINST THIS SOLICITATION. PLEASE CHECK ALL THAT APPLY:

☐ BIDDER PERMITS ANY CONTRACT AWARDED TO APPLY TO QUASI STATE AGENCIES OR OTHER POLITICAL SUBDIVISIONS OF THE STATE.

☐ BIDDER PERMITS ANY CONTRACT AWARDED TO APPLY TO AGENCIES OF THE UNITED STATE GOVERNMENT.

☐ BIDDER PERMITS ANY CONTRACT AWARDED TO APPLY TO OTHER BUYING ORGANIZATIONS (OTHER THAN THE UNITED STATES GOVERNMENT), NOT LOCATED IN THIS STATE WHICH, IF LOCATED IN THIS STATE, WOULD QUALIFY AS A PUBLIC PROCUREMENT UNIT.

11. ACCEPTANCE. UNLESS OTHERWISE SPECIFIED, BIDS ON THIS CONTRACT WILL BE ASSUMED TO BE FIRM FOR ACCEPTANCE FOR A MINIMUM OF 60 DAYS. IF ACCEPTED, PRICES MUST BE FIRM FOR THE SPECIFIED CONTRACT PERIOD.

12. CONTRACT REVISIONS. REQUESTS FOR REVISIONS TO THIS CONTRACT MUST BE ADDRESSED TO THE DIRECTOR OF STATE PURCHASING AND SHALL REFER THE CONTRACT ITEM NUMBER WITH JUSTIFICATION OF THE REQUEST. DISTRIBUTOR VENDOR CHANGES, PRICE REDUCTIONS AND JUSTIFIABLE ITEM DELETIONS MAY BE CONSIDERED DURING THE CONTRACT PERIOD. NEW ITEM ADDITIONS WILL BE CONSIDERED ONLY ON THE ANNIVERSARY DATE OF THE CONTRACT. EXCEPTIONS TO THIS WILL BE ALLOWED ONLY WHEN STATE PURCHASING HAS DETERMINED ADDITIONS WILL BE OF SUBSTANTIAL BENEFIT TO THE STATE AND WILL JUSTIFY THE TIME, EFFORT AND COST REQUIRED TO MAKE SUCH ADDITIONS.

CONTRACTOR MUST IMMEDIATELY NOTIFY THE OFFICE OF STATE PURCHASING WHEN ANY DEALER ON THIS CONTRACT IS TERMINATED, RELOCATED OR ADDED. ALL ORDERS PLACED WITH DEALERS PRIOR TO RECEIPT OF SUCH NOTIFICATION BY THE OFFICE OF STATE PURCHASING MUST BE HONORED. REVISIONS WILL BECOME EFFECTIVE ONLY UPON APPROVAL BY THE DIRECTOR OF STATE PURCHASING OR DESIGNEE. BIDDER SHOULD INCLUDE WITH BID A LIST OF ALL PERSONS, IN ADDITION TO THE SIGNER OF THIS BID, WHO ARE AUTHORIZED TO REQUEST REVISIONS TO THIS CONTRACT.

13. CANCELLATION. THE STATE OF LOUISIANA RESERVES THE RIGHT TO CANCEL THIS CONTRACT WITH THIRTY (30) DAYS WRITTEN NOTICE.

14. QUANTITIES. THIS IS AN OPEN-ENDED REQUIREMENTS CONTRACT. QUANTITIES SHOWN ARE BASED ON THE PREVIOUS CONTRACT USAGE OR ESTIMATES. WHERE USAGE IS NOT AVAILABLE, A QUANTITY OF 1 INDICATES A LACK OF HISTORY ON THIS ITEM. THE SUCCESSFUL BIDDER MUST SUPPLY AT BID PRICES ACTUAL REQUIREMENTS AS ORDERED WHETHER THE TOTAL OF SUCH REQUIREMENTS ARE MORE OR LESS THAN THE QUANTITIES SHOWN.

15. ORDERS. ALL STATE AGENCIES ARE TO ISSUE CONTRACT RELEASE ORDERS FOR THE ITEMS REQUIRED, AS AND WHEN NEEDED. POLITICAL SUBDIVISIONS OF THE STATE AND QUASI AGENCIES WHO HAVE BEEN AUTHORIZED TO PURCHASE FROM CONTRACTS MADE BY THE OFFICE OF STATE PURCHASING, ARE TO ISSUE THEIR REGULAR PURCHASE ORDERS DIRECTLY TO THE SUPPLIER, MAKING

SPECIAL TERMS & CONDITIONS		INVITATION TO BID	
NUMBER : 2238331 OPEN DATE: 02/25/10 T-NUMBER : 92084		BIDDER:	PAGE 7
<div>REFERENCE TO THE CONTRACT AND ITEM NUMBER.</div> <div>3 COMPLIANCE WITH CIVIL RIGHTS LAWS. BY SUBMITTING AND SIGNING THIS SOLICITATION, THE BIDDER AGREES TO ABIDE BY THE REQUIREMENTS OF THE FOLLOWING AS APPLICABLE: TITLE VI AND TITLE VII OF THE CIVIL RIGHTS ACT OF 1964, AS AMENDED BY THE EQUAL OPPORTUNITY ACT OF 1972, FEDERAL EXECUTIVE ORDER 11246, THE FEDERAL REHABILITATION ACT OF 1973, AS AMENDED, THE VIETNAM ERA VETERAN'S READJUSTMENT ASSISTANCE ACT OF 1974, TITLE IX OF THE EDUCATION AMENDMENTS OF 1972, THE AGE ACT OF 1975, AND BIDDER AGREES TO ABIDE BY THE REQUIREMENTS OF THE AMERICANS WITH DISABILITIES ACT OF 1990. BIDDER AGREES NOT TO DISCRIMINATE IN ITS EMPLOYMENT PRACTICES, AND WILL RENDER SERVICES UNDER ANY CONTRACT ENTERED INTO AS A RESULT OF THIS SOLICITATION, WITHOUT REGARD TO RACE, COLOR, RELIGION, SEX, SEXUAL ORIENTATION, NATIONAL ORIGIN, VETERAN STATUS, POLITICAL AFFILIATION, OR DISABILITIES. ANY ACT OF DISCRIMINATION COMMITTED BY BIDDER, OR FAILURE TO COMPLY WITH THESE STATUTORY OBLIGATIONS WHEN APPLICABLE, SHALL BE GROUNDS FOR TERMINATION OF ANY CONTRACT ENTERED INTO AS A RESULT OF THIS SOLICITATION.</div> <div>4 PREFERENCE. IN ACCORDANCE WITH LOUISIANA REVISED STATUTES 39:1595, A PREFERENCE MAY BE ALLOWED FOR PRODUCTS MANUFACTURED, PRODUCED, GROWN, OR ASSEMBLED IN LOUISIANA OF EQUAL QUALITY.</div> <div>DO YOU CLAIM THIS PREFERENCE? YES</div> <div>SPECIFY LINE NUMBER(S) :</div> <div>SPECIFY LOCATION WITHIN LOUISIANA WHERE THIS PRODUCT IS MANUFACTURED, PRODUCED, GROWN OR ASSEMBLED:</div> <div>(NOTE: IF MORE SPACE IS REQUIRED, INCLUDE ON SEPARATE SHEET.)</div> <div>DO YOU HAVE A LOUISIANA BUSINESS WORKFORCE? YES NO</div> <div>IF SO, DO YOU CERTIFY THAT AT LEAST FIFTY PERCENT (50%) OF YOUR LOUISIANA BUSINESS WORKFORCE IS COMPRISED OF LOUISIANA RESIDENTS?</div> <div>YES NO</div> <div>FAILURE TO SPECIFY ABOVE INFORMATION MAY CAUSE ELIMINATION FROM PREFERENCES. PREFERENCES SHALL NOT APPLY TO SERVICE CONTRACTS.</div> <div>5 CANCELLATION THE STATE OF LOUISIANA RESERVES THE RIGHT TO CANCEL THIS CONTRACT WITH THIRTY (30) DAYS WRITTEN NOTICE.</div> <div>6 CERTIFICATION OF NO SUSPENSION OR DEBARMENT. BY SIGNING AND SUBMITTING ANY BID FOR \$100,000 OR MORE, THE BIDDER CERTIFIES THAT THEIR COMPANY, ANY SUBCONTRACTORS, OR PRINCIPALS ARE NOT SUSPENDED OR DEBARRED BY THE GENERAL SERVICES ADMINISTRATION (GSA) IN ACCORDANCE</div>			

SPECIAL TERMS & CONDITIONS		INVITATION TO BID	
NUMBER : 2238331 OPEN DATE: 02/25/10 TIME: 10:00 AM T-NUMBER : 92084		BIDDER:	PAGE 8

WITH THE REQUIREMENTS IN OMB CIRCULAR A-133.

_____ A LIST OF PARTIES WHO HAVE BEEN SUSPENDED OR DEBARRED CAN BE VIEWED
 _____ VIA THE INTERNET AT WWW.EPLS.GOV

7 CONTRACT PERFORMANCE EVALUATION
 IN AN EFFORT TO IMPROVE OUR CONTRACTS TO MEET THE NEEDS OF THE AGENCIES WE SERVE, THE CONTRACTOR'S PERFORMANCE WILL BE MONITORED. AGENCIES' FEEDBACK WILL BE REQUESTED REGARDING CUSTOMER SERVICE, DELIVERY, PRODUCT QUALITY, BILLING, OVERALL EFFECTIVENESS OF THE CONTRACT, AND ANY NEEDED CHANGES. THEIR RESPONSES WILL BE CONSIDERED IN DETERMINING OUR OPTIONS FOR RENEWALS OR REVISIONS AND REBIDDING. TO VIEW THE CONTENT OF THE CONTRACT PERFORMANCE EVALUATION FORM, GO TO [HTTP://WWW.DOA.LA.GOV/OSP/ONLINEFORMS/SUBMIT/CONTRPERFORMANCE.PDF](http://www.doa.la.gov/osp/onlineforms/submit/contrperformance.pdf) OR CALL FOR A COPY.

AGENCY REPORTS OF DEFICIENT PERFORMANCE WILL BE APPROPRIATELY ADDRESSED DURING THE CONTRACT PERIOD.

8 LACARTE PROCUREMENT CARD - PROSPECTIVE VENDORS SHOULD BE AWARE THAT THE STATE HAS IMPLEMENTED A PURCHASING CARD PROGRAM, "LACARTE", WHICH USES A VISA CARD PLATFORM. VENDORS WILL BE ABLE TO RECEIVE PAYMENT FROM STATE AGENCIES USING THE CARD IN THE SAME MANNER AS OTHER VISA CARD PURCHASES.

UNDER THE "LACARTE" PROGRAM PURCHASE ORDERS ARE NOT NECESSARY. ORDERS MUST BE PLACED AGAINST THE NET DISCOUNTED PRODUCTS OF THE CONTRACT. ALL CONTRACT TERMS AND CONDITIONS APPLY TO PURCHASES MADE WITH "LACARTE"; HOWEVER, A VENDOR SHALL NOT PROCESS A TRANSACTION FOR PAYMENT THROUGH THE CREDIT CARD CLEARINGHOUSE UNTIL THE PURCHASED PRODUCTS HAVE BEEN SHIPPED OR THE SERVICES PERFORMED.

IF A PURCHASE ORDER IS NOT USED, THE VENDOR MUST KEEP ON FILE A RECORD OF ALL "LACARTE" PURCHASES ISSUED AGAINST THIS CONTRACT DURING THE CONTRACT PERIOD. THE FILE MUST CONTAIN THE PARTICULAR ITEM NUMBER, QUANTITY, LINE TOTAL AND ORDER TOTAL. RECORDS OF THESE PURCHASES MUST BE PROVIDED TO THE OFFICE OF STATE PURCHASING ON REQUEST.

"LACARTE" ACCEPTANCE IS NOT A MANDATORY REQUIREMENT OF THIS CONTRACT NOR WILL IT BE THE EXCLUSIVE METHOD OF PAYMENT BY AGENCIES.

DO YOU AGREE TO ACCEPT "LACARTE" AS A PAYMENT OPTION, SHOULD YOU BE AWARDED THIS CONTRACT?

_____ YES _____ NO

9 LA ECAT - LOUISIANA'S ECAT PROVIDES AN INTERNET-BASED SHOPPING TOOL FOR PLACEMENT OF CONTRACT ORDERS. USERS OF THE CONTRACTS ARE ABLE TO SHOP VIA THE INTERNET, CREATE SHOPPING BASKETS, AND PLACE ORDERS ONLINE. ORDERS ARE SENT ELECTRONICALLY TO THE VENDOR, WITH EMAIL NOTIFICATION THAT THE ORDER HAS BEEN ISSUED AND IS WAITING FOR THEM TO RETRIEVE IT. AFTER RECEIVING THIS NOTIFICATION, THE CONTRACT VENDOR HAS THE ABILITY TO LOG INTO LA ECAT AND RETRIEVE HIS PURCHASE ORDERS, THEREBY AVOIDING DELAYS ASSOCIATED WITH NORMAL MAIL. MORE INFORMATION IS AVAILABLE AT THE FOLLOWING WEBSITE:
[HTTP://DOA.LOUISIANA.GOV/OSP/ECAT/ECAT.HTM](http://doalouisiana.gov/osp/ecat/ecat.htm).

SPECIAL TERMS & CONDITIONS		INVITATION TO BID	
NUMBER : 2238331 OPEN DATE: 02/25/10 TIME: 10:00 AM T-NUMBER : 92084		BIDDER:	PAGE 9

IF YOU ARE CURRENTLY ENROLLED IN LA ECAT AND ARE AWARDED THIS CONTRACT, ANY ORDERS PLACED THROUGH LA ECAT WILL BE SENT TO YOU ELECTRONICALLY.

IF YOU ARE NOT CURRENTLY ENROLLED IN LA ECAT, BUT WOULD LIKE TO ENROLL IN THE EVENT YOU ARE AWARDED THIS CONTRACT, SIMPLY PROVIDE THE INFORMATION BELOW.

_____ YES, SIGN ME UP FOR FREE PARTICIPATION IN LA ECAT.

COMPANY NAME: _____

EMAIL ADDRESS: _____

CONTACT PERSON: _____

CONTACT PHONE: _____

10

NOTE: SECTION 10 PERTAINS ONLY TO STATIONARY DIESEL AND NATURAL GAS GENERATORS.

GENERAL: THESE SPECIFICATIONS DESCRIBE THE MINIMUM REQUIREMENTS FOR DIESEL & NATURAL GAS GENERATORS W/AUTOMATIC TRANSFER. EQUIPMENT SHALL BE NEW, OF CURRENT MANUFACTURE, A PRODUCTION MODEL, AND MUST MEET ALL STATE AND FEDERAL SAFETY STANDARDS IN EFFECT AT TIME OF DELIVERY. ANY ADDITIONS DELETIONS, OR VARIATIONS FROM THE FOLLOWING SPECIFICATIONS MUST BE NOTED. ANY ITEMS, APPEARING IN THE MANUFACTURER'S REGULAR PUBLISHED SPECIFICATIONS FURNISHED BY THE BIDDER ARE ASSUMED TO BE INCLUDED IN THE "BIDDER'S PROPOSAL." ANY ADDITIONS, DELETIONS, OR VARIATIONS FROM THE MANUFACTURER'S REGULAR PUBLISHED SPECIFICATIONS SHOULD BE OUTLINED IN AN ATTACHED LETTER. MINOR DEVIATIONS FROM THIS SPECIFICATION WHICH DO NOT IMPAIR COMPARATIVE FUNCTIONAL EQUIVALENCY WILL BE ACCEPTED.

WORKMANSHIP: ANY UNIT DELIVERED UNDER THIS SPECIFICATION IS SUBJECT TO REJECTIONS IF THERE IS EVIDENCE OF POOR WORKMANSHIP, BY EITHER THE VENDOR OR THE ORIGINAL MANUFACTURER. ANY DEFECT SO NOTED, MAY BE CORRECTED BY THE VENDOR TO THE SATISFACTION OF THE AGENCY REPRESENTATIVE.

ALL DEFECT CORRECTIONS MUST BE COMPLETED BEFORE INVOICES CAN BE PROCESSED FOR PAYMENT.

VENDOR INSTALLATION OF ANY PORTION OF EQUIPMENT UNITS MUST BE STATED IN "BIDDER'S PROPOSAL." FAILURE TO NOTE SUCH INSTALLATIONS CAN RESULT IN REJECTION OF THE UNIT(S) AT THE TIME OF DELIVERY.

USAGE VOLUME:

THE VENDOR WILL BE REQUIRED TO FURNISH THE OFFICE OF STATE PURCHASING USAGE REPORTS WITHIN TEN (10) DAYS OF REQUEST. THE USAGE REPORT WILL INCLUDE USAGE BY STATE AGENCIES, QUASI-AGENCIES/POLITICAL SUBDIVISIONS. THE USAGE REPORTS WILL BE BROKEN DOWN INTO THE FOLLOWING:

SPECIAL TERMS & CONDITIONS		INVITATION TO BID	
NUMBER : 2238331 OPEN DATE: 02/25/10 T-NUMBER : 92084		BIDDER:	PAGE 10
<div></div> <div></div> <div></div> <p>STATE AGENCIES: QUANTITY BY CONTRACT LINE AND TOTAL DOLLAR BY LINE.</p> <p>QUASI-AGENCIES/POLITICAL SUBDIVISIONS: QUANTITY BY CONTRACT LINE AND TOTAL DOLLAR BY LINE.</p> <p>THE PREFERRED FORMAT FOR THE USAGE REPORT IS BY ELECTRONIC MEANS.</p> <p>NON-EXCLUSIVITY: THIS AGREEMENT IS NON-EXCLUSIVE AND SHALL NOT IN ANY WAY PRECLUDE STATE AGENCIES FROM ENTERING INTO SIMILAR AGREEMENTS AND/OR ARRANGEMENTS WITH OTHER VENDORS OR FROM ACQUIRING SIMILAR, EQUAL, OR LIKE GOODS AND/OR SERVICES FROM OTHER ENTITIES OR SOURCES.</p> <p>SPECIFICATION DESCRIPTION</p> <p>THE SYSTEM SHALL BE A PACKAGE OF NEW AND CURRENT EQUIPMENT CONSISTING OF:</p> <ol style="list-style-type: none">1) A DIESEL OR NATURAL GAS ENGINE DRIVEN ELECTRIC GENERATING SET TO PROVIDE STANDBY POWER.2) AN ENGINE START-STOP CONTROL SYSTEM MOUNTED ON THE GENERATING SET.3) AN AUTOMATIC LOAD TRANSFER CONTROL TO PROVIDE AUTOMATIC STARTING AND STOPPING OF THE ENGINE AND SWITCHING OF THE LOAD.4) MOUNTED ACCESSORIES AS SPECIFIED.5) SUCCESSFUL BIDDER SHALL BE RESPONSIBLE FOR COMPLETE ENGINE-GENERATOR SET, AUTOMATIC TRANSFER SWITCH, TESTING AND WARRANTY OF ALL EQUIPMENT INSTALLED. THE VENDOR IS RESPONSIBLE FOR THE COORDINATION BETWEEN MANUFACTURER, SERVICE FIRM AND INSTALLER. <p>THE PERFORMANCE OF THIS SPECIFIC GENERATING SET SHALL BE CERTIFIED BY A FACTORY TEST AS TO THE SET'S FULL POWER RATING, STABILITY, VOLTAGE AND FREQUENCY REGULATION. ALSO DOCUMENT OF THESE TEST SHALL BE PROVIDED.</p> <p>THIS STANDBY ELECTRIC POWER SYSTEM SHALL BE WARRANTED FOR A PERIOD OF FIVE YEARS FROM DATE OF INITIAL START UP AS DESCRIBED IN GREATER DETAIL LATER.</p> <p>MANUFACTURER QUALIFICATION: FIRM REGULARLY ENGAGED IN THE MANUFACTURING OF ENGINE AND/OR GENERATOR AND PRODUCTIONS OF ENGINE-GENERATOR SETS FOR NOT LESS THAN FIVE YEARS. FURNISH PROOF, UPON REQUEST. MANUFACTURER MUST HAVE SERVICE FIRM, THAT HAS BEEN FACTORY AUTHORIZED.</p> <p>MANUFACTURER: SINGLE VENDOR RESPONSIBILITY FOR COMPLETE ENGINE-GENERATOR SET, AUTOMATIC TRANSFER SWITCH, CONTROLS, FACTORY TESTS, FACTORY WARRANTY AND SHIPPING. COORDINATION BETWEEN MANUFACTURER, SERVICE FIRM AND THE DEPARTMENT IS MANDATORY.</p>			

SPECIAL TERMS & CONDITIONS		INVITATION TO BID	
NUMBER : 2238331 OPEN DATE: 02/25/10 TIME: 10:00 AM T-NUMBER : 92084		BIDDER:	PAGE 11
<p>THE MANUFACTURER SHALL HAVE PRINTED LITERATURE AND BROCHURES DESCRIBING THE STANDARD SERIES OFFERED (NOT A ONE OF A KIND FABRICATION). THE MANUFACTURER SHALL FURNISH SCHEMATIC AND WIRING DIAGRAMS FOR THE ENGINE-ALTERNATOR SET.</p> <p>THE PERFORMANCE OF THE GENERATING SET SERIES SHALL BE IN ACCORDANCE WITH PROCEDURES CERTIFIED BY AN INDEPENDENT TESTING LABORATORY, OR THE GENERATER SET SERIES SHALL BE ISO 9001 CERTIFIED.</p> <p>SUPPLIER QUALIFICATION: FIRM ENGAGED IN SUPERVISING INSTALLATION OF AND SERVICING ENGINE-GENERATOR SETS. FIRM WHO IS AND HAS BEEN, PRIOR TO BID DATE, A FACTORY AUTHORIZED SERVICE ORGANIZATION, IN LOUISIANA. FIRM MUST MAINTAIN STOCK OF STANDARD SPARE PARTS, FREE 24-HOUR DELIVERY ON PARTS NOT STOCKED, MAINTAIN STAFF OF EXPERIENCED TECHNICIANS SPECIFICALLY TRAINED IN SERVICING ENGINE-GENERATOR SETS AND HAVE PERSONNEL AVAILABLE ON 24 HOUR PER DAY 7 DAYS PER WEEK CALL BASIS.</p> <p>ENGINE: THE ENGINE SHALL BE DIESEL OR NATURAL GAS FUELED, WATER COOLED WITH MOUNTED RADIATOR, FAN AND WATER PUMP. THE ENGINE SHALL BE ADEQUATE FOR CAPACITY OF GENERATOR. IT SHALL HAVE AN OPERATING SPEED OF 1800 RPM. INTAKE AND EXHAUST VALVES SHALL BE HEAT RESISTING ALLOY STEEL, FREE ROTATING. EXHAUST VALVE SEAT INSERTS SHALL BE PROVIDED. FULL PRESSURE LUBRICATION SHALL BE SUPPLIED BY A POSITIVE DISPLACEMENT LUBE OIL PUMP. THE ENGINE SHALL HAVE COOLANT AND OIL FILTERS WITH REPLACEABLE ELEMENTS; AND A FUEL TRANSFER PUMP CAPABLE OF 36" FUEL LIFT. ENGINE SPEED SHALL BE GOVERNED BY A GOVERNOR TO MAINTAIN ALTERNATOR FREQUENCY WITHIN 3 HERTZ, FROM NO LOAD TO FULL LOAD ALTERNATOR OUTPUT. A CRITICAL GRADE EXHAUST SILENCER SHALL BE FURNISHED. REMOTE 2/3 WIRE STARTING SHALL BE BY A 12 OR 24 VOLT SOLENOID SHIFT ELECTRIC STARTER. A SHUT-OFF VALVE AND HOSE TO DRAIN OIL FROM CRANKCASE. LOW COOLANT ALARM. ENGINE CRANKCASE SHALL BE FILLED WITH OIL. COOLANT SYSTEM WITH 50% ANTI-FREEZE/WATER MIXTURE.</p> <p>JACKET HEATER: THE ENGINE SHALL HAVE AT LEAST A 750 WATT WATER JACKET HEATER.</p> <p>ENGINE INSTRUMENTS: THE ENGINE INSTRUMENT PANEL SHALL CONTAIN AN OIL PRESSURE INDICATOR, COOLANT TEMPERATURE INDICATOR, AND BATTERY VOLTAGE INDICATOR, AMMETER.</p> <p>ENGINE CONTROLS: THE GENERATING SET SHALL CONTAIN A COMPLETE ENGINE START-STOP CONTROL WHICH STARTS ENGINE ON CLOSING CONTACT AND STOPS ENGINE ON OPENING CONTACT. THE GENERATING SET SHALL HAVE CYCLE CRANKING AND ALSO A CRANKING LIMITER SHALL BE PROVIDED TO OPEN THE STARTING CIRCUIT IN APPROXIMATELY 45 TO 90 SECONDS IF THE ENGINE IS NOT STARTED WITHIN THAT TIME. THE ENGINE CONTROLS SHALL ALSO INCLUDE A MANUAL 3 POSITION SELECTOR SWITCH OR FUNCTIONAL EQUIVALENT WITH: RUN-STOP-AUTOMATIC. THE ENGINE SHALL HAVE THE FOLLOWING ADDITIONAL EQUIPMENT: SAFETY SHUTDOWN SYSTEM INCLUDING LOW OIL PRESSURE, HIGH ENGINE TEMPERATURE, OVERSPEED, OVERCRANK, AND MANUAL STOP.</p> <p>BRUSHLESS ALTERNATOR: THE ALTERNATOR SHALL BE 4 POLE, REVOLVING FIELD TYPE DESIGN WITH TEMPERATURE COMPENSATED SOLID STATE VOLTAGE REGULATOR AND BRUSHLESS ROTATING RECTIFIER EXCITER SYSTEM. NO BRUSHES SHALL BE</p>			

SPECIAL TERMS & CONDITIONS		INVITATION TO BID	
NUMBER : 2238331 OPEN DATE: 02/25/10 TIME: 10:00 AM T-NUMBER : 92084		BIDDER:	PAGE 12
<p>ALLOWED. THE STATOR SHALL BE DIRECTLY CONNECTED TO THE ENGINE FLYWHEEL HOUSING AND THE ROTOR SHALL BE DRIVEN THRU A SEMI-FLEXIBLE DRIVING FLANGE TO INSURE PERMANENT ALIGNMENT. THE INSULATION SYSTEM SHALL BE AT LEAST CLASS H DEFINED BY NEMA MG1.65. THE ROTOR AND STATOR TO BE 100% FILLED WITH HIGH BONDING RIGID EPOXY. SYSTEMS WHICH USE SOLVENT BASE SUCH AS VARNISH OR OTHER TYPES OF EPOXY THAT ARE NOT 100% FILLED WILL NOT BE ACCEPTABLE.</p> <p>ALTERNATOR INSTRUMENT: THE ALTERNATOR INSTRUMENT PANEL SHALL BE WIRED, TESTED AND SHOCK MOUNTED ON THE GENERATING SET. IT SHALL CONTAIN PANEL LIGHTING, MANUAL RESET FIELD CIRCUIT BREAKER, RUNNING TIME METER, VOLTAGE ADJUSTING RHEOSTAT.</p> <p>UNIT PERFORMANCE: THE UNIT PERFORMANCE SHALL BE IN COMPLIANCE WITH UL2200. FREQUENCY REGULATION SHALL NOT EXCEED 3 HERTZ FROM NO LOAD TO RATED LOAD. VOLTAGE REGULATION SHALL BE WITHIN PLUS OR MINUS 2 PERCENT OF RATED VOLTAGE, FROM NO LOAD TO FULL RATED LOAD. THE INSTANTANEOUS DIP SHALL BE LESS THAN 25% OF RATED VOLTAGE UNLESS OTHERWISE SPECIFIED WHEN FULL 3 PHASE LOAD AND RATED POWER FACTOR IS APPLIED TO THE ALTERNATOR. RECOVERY TO STABLE OPERATION SHALL OCCUR WITHIN TWO SECONDS. STABLE OR STEADY STATE OPERATION IS DEFINED AS OPERATION WITH TERMINAL VOLTAGE REMAINING CONSTANT WITHIN PLUS OR MINUS 1% OF RATED VOLTAGE. A RHEOSTAT SHALL BE PROVIDED, A MINIMUM OF PLUS OR MINUS 5% VOLTAGE ADJUSTMENT FROM RATED VALUE. TEMPERATURE RISE SHALL BE WITHIN NEMA MG1-22.40 DEFINITION. THE RATING OF THE PRIME MOVER SHALL BE SUCH THAT ANY OVER-LOADS WHICH OCCUR DURING MOTOR STARTING, EVEN THOUGH THEY MAY EXCEED THE STEADY STATE CAPABILITY OF THE PRIME MOVER, SHALL NOT CAUSE STALLING.</p> <p>SAFETY SHUTDOWN MONITORING SYSTEM: THE ELECTRIC GENERATING PLANT SHALL BE PROVIDED WITH AN ALARM AND LIGHT INDICATING NOT IN AUTOMATIC, AND AUTOMATIC SAFETY SHUTDOWNS INCLUDING INDIVIDUAL ALARM TERMINALS PLUS INDIVIDUAL INDICATING LIGHTS REVEALING WHICH SAFETY CAUSED SHUTDOWN OR FUNCTIONAL EQUIVALENT. THIS MONITORING SYSTEM SHALL HAVE THE FOLLOWING:</p> <p>RUN SWITCH OFF OVERCRANK SHUTDOWN OVERSPEED SHUTDOWN LOW OIL PRESSURE SHUTDOWN HIGH ENGINE TEMPERATURE SHUTDOWN HIGH ENGINE TEMPERATURE PREALARM LOW ENGINE OIL PRESSURE PREALARM LOW COOLANT TEMPERATURE LOW FUEL</p> <p>A FRONT CONTROL PANEL ILLUMINATION LAMP WITH ON/OFF SWITCH OR OR FUNCTIONAL EQUIVALENT SHALL BE PROVIDED. CONTROL PANEL MOUNTED INDICATING METERS AN DEVICES SHALL INCLUDE:</p> <p>ENGINE OIL PRESSURE, COOLANT TEMPERATURE, DC VOLTAGE, RUN TIME (IN 10TH OF HOURS), AC VOLTAGE, AND AC AMPHERAGE INDICATOR, FREQUENCY INDICATION.</p> <p>AC RHEOSTAT (PANEL MOUNTED) FOR + 5% VOLTAGE ADJUSTMENT.</p>			

SPECIAL TERMS & CONDITIONS		INVITATION TO BID	
NUMBER : 2238331 OPEN DATE: 02/25/10 TIME: 10:00 AM T-NUMBER : 92084		BIDDER:	PAGE 13
<p>AN INLINE CIRCUIT BREAKER SHALL BE PROVIDED.</p> <p>PROTECTION: GENERATOR SHOULD BE OF THE INHERENT SELF PROTECTION DESIGN HAVING OVERCURRENT AND OVERLOAD INHERENT PROTECTION IN ACCORDANCE WITH NEC ARTICLE 445-4.</p> <p>ELECTRIC PLANT MOUNTING: THE ELECTRIC PLANT SHALL HAVE BUILT-IN VIBRATION ISOLATORS AND BE MOUNTED ON WELDED STEEL BASE WHICH SHALL PERMIT SUITABLE MOUNTING TO ANY LEVEL SURFACE.</p> <p>VIBRATION ISOLATORS: - VIBRATION ISOLATOR SHALL BE PROVIDED FOR INSTALLATION BENEATH ELECTRIC PLANT SKID AND MOUNTING SURFACE AND SHALL BE PROPERLY ANCHORED TO MOUNTING SURFACE.</p> <p>BATTERIES: ONE OR TWO, (DEPENDING ON STARTING VOLTAGE) 12-VOLT HEAVY DUTY LEAD ACID STARING BATTERIES WITH ELECTROLYTE SHALL BE PROVIDED.</p> <p>BATTERY RACKS: BATTERY RACKS SHALL BE BUILT INTO ELECTRIC PLANT SKID.</p> <p>BATTERY CHARGER: A VOLTAGE REGULATED CURRENT LIMITED BATTERY FLOAT CHARGER TO MAINTAIN FULLY CHARGED CRANKING BATTERIES SHALL BE PROVIDED, MINIMUM 2 AMP.</p> <p>AUTOMATIC TRANSFER SWITCH</p> <p>GENERAL: THE AUTOMATIC TRANSFER SWITCH SHALL BE SERVICED BY THE MANUFACTURER OF THE EMERGENCY AC POWER GENERATOR SO AS TO MAINTAIN SYSTEM COMPATIBILITY AND SERVICE RESPONSIBILITY FOR COMPLETE EMERGENCY POWER SYSTEM. A MANUFACTURER'S REPRESENTATIVE SHALL CONDUCT A COMPLETE SYSTEM OPERATIONAL TEST FOR THE ENGINEER OR HIS REPRESENTATIVE AND THE OPERATING PERSONNEL.</p> <p>IT SHALL BE LISTED BY UNDERWRITERS LABORATORIES (STD 1008), AND TRANSFER SWITCHES SUPPLIED SHALL BEAR THE UL LABEL. THE GENERATOR/ TRANSFER SWITCH MANUFACTURER SHALL FURNISH SCHEMATIC AND ALSO WIRING DIAGRAMS FOR THE PARTICULAR AUTOMATIC TRANSFER SWITCH AND INTERCONNECTING WIRING DIAGRAMS FOR THE ENTIRE STANDBY SYSTEM. AS WELL AS ACCESS CODES TO ANY PROGRAMABLE SYSTEM.</p> <p>RATING AND PERFORMANCE: THE AUTOMATIC TRANSFER SWITCH SHALL BE RATED FOR CONTINUOUS OPERATION IN AMBIENT TEMPERATURES OF AT LEAST -30C TO +70C. THE AUTOMATIC TRANSFER SWITCH SHALL BE RATED FOR ALL CLASSES OF LOAD, BOTH INDUCTIVE AND RESISTIVE. THE VOLTAGE RATING OF THE TRANSFER SWITCH SHALL BE NO LESS THAN 600 VOLTS. THE TRANSFER SWITCH CONTACT SHALL BE RATED FOR USE UP TO 600 VOLTS. THE AUTOMATIC TRANSFER SWITCH SHALL BE DESIGNED, BUILT AND TESTED FOR NON-WELDING OF CONTACTS WHEN INTRODUCED TO AN OVERCURRENT. IT SHALL BE CAPABLE OF SWITCHING LOADS UP TO AND INCLUDING ITS INTERRUPTING CURRENT CAPACITY.</p> <p>CONSTRUCTION: THE AUTOMATIC TRANSFER SWITCH SHALL HAVE MAIN CONTACTS OF HIGH PRESSURE DESIGN PROVIDING CONTINUOUS OPERATION, LONG LIFE AND RESISTANCE TO BURNING, PITTING AND WELDING. THE CONTACT MECHANISM</p>			

SPECIAL TERMS & CONDITIONS		INVITATION TO BID	
NUMBER : 2238331 OPEN DATE: 02/25/10 TIME: 10:00 AM T-NUMBER : 92084		BIDDER:	PAGE 14
<p>SHALL BE VERTICAL CONSTRUCTION AND SHALL OPERATE ON A SINGLE SHAFT. WHEN IN THE NORMAL OR EMERGENCY POSITION, THE TRANSFER MECHANISM SHALL BE MECHANICALLY LOCKED IN THAT POSITION. THE TRANSFER SWITCH SHALL POSITIVELY PREVENT CONTACT CLOSURE IN BOTH POSITIONS SO THAT BOTH SOURCES CANNOT SUPPLY THE LOAD SIMULTANEOUSLY. (MECHANICALLY INTERLOCKED) .</p> <p>THE TRANSFER SWITCH SHALL HAVE INDIVIDUAL, FULLY ENCLOSED ARC CHUTES PROVIDING RAPID ARC QUENCHING, WITHOUT CROSS ARCING. A STURDY SAFETY ENCLOSURE SHALL SURROUND AREAS OF ARCING AND MECHANICAL HAZARD. IT SHALL HAVE TERMINAL LUGS FOR EITHER COPPER OR ALUMINUM CONDUCTORS. MANUAL OPERATIONS SHALL BE PROVIDED TO ALLOW SAFE MANUAL OPERATION OF THE SWITCHING SPEED OR PRECISION. MANUAL OPERATION SHALL BE A PERMANENT PART OF THE OPERATING MECHANISM. IT SHALL BE CAPABLE OF BEING SAFELY SWITCHED MANUALLY WHILE UNDER LOAD.</p> <p>THE TRANSFER SWITCH SHALL HAVE AUXILIARY CONTACTS ON BOTH NORMAL AND EMERGENCY SIDES OFFERING THE OPTION OF SIGNAL TO PILOT CIRCUITS OR REMOTE INDICATION. IT SHALL HAVE A NEUTRAL BAR FOR EASE IN TIEING THE NEUTRAL CONDUCTORS.</p> <p>MAXIMUM INSTANTANEOUS PEAK LET THROUGH CURRENT OF 200,000 AMPS WHEN USED WITH A CURRENT LIMITING FUSE CLEARING IN ONE-HALF CYCLE OR LESS.</p> <p>CONTROL ACCESSORIES SHALL MOUNT ON A DEAD-FRONT, SWING OUT CONTROL ACCESSORY PANEL MOUNTED ON THE ENCLOSURE BACK PLATE, PROTECTED TO AVOID SHOCK HAZARD WHILE ADJUSTING CONTROL FUNCTION, BUT WILL PROVIDE ACCESS TO WIRING TO FACILITATE SERVICING. INDICATING LAMPS SHALL BE SET IN FRONT MOUNTED PANEL. COMPLETE AUTOMATIC TRANSFER SWITCH SHALL BE MOUNTED IN NEMA 3 R RAIN TIGHT ENCLOSURE, PRIMED AND PAINTED.</p> <p>EQUIPMENT & OPERATION: AUTOMATIC TRANSFER SWITCH WITH SOLID STATE CONTROL SHALL PROVIDE THE FOLLOWING FUNCTIONS:</p> <p>IT SHALL MONITOR EACH UNDERGROUNDED LINE WITH ADJUSTABLE SOLID STATE UNDERVOLTAGE SENSORS TO SENSE A DECREASE OF VOLTAGE BELOW A SET POINT, OR A LOSS OF VOLTAGE ON ANY PHASE OF THE NORMAL POWER SOURCE. VOLTAGE SENSORS SHALL BE TEMPERATURE COMPENSATED FOR TWO PERCENT MAXIMUM DEVIATION OVER THE TEMPERTURE RANGE OF AT LEAST -30C TO +70C.</p> <p>SHALL PROVIDE A PROGRAMMABLE NEUTRAL POSITION PERMITTING VOLTAGES GENERATED BY INDUCTIVE OR MOTOR LOADS TO DECAY BEFORE TRANSFER OR RETRANSFER OF LOADS WHEN EXERCISING THE PLANT UNDER LOAD. THIS TIME DELAY SHALL BE ADJUSTABLE IN A RANGE OF AT LEAST 1 SECOND TO 5 SECONDS TO MOMENTARILY STOP THE TRANSITION OF THE LOAD TRANSFER IN THE NEUTRAL POSITION FOR A PRESET TIME PERIOD.</p> <p>SIGNAL THE ENGINE GENERATOR SET TO START IN THE EVENT OF A POWER INTERRUPTION. A SOLID STATE TIME DELAY START, ADJUSTABLE FROM AT LEAST 1 TO 6 SECONDS SHALL DELAY THIS SIGNAL TO AVOID NUISANCE STARTUPS ON MOMENTARY VOLTAGE DIPS OR POWER OUTAGES. FACTORY SET AT 2 SECONDS.</p> <p>TRANSFER THE LOAD TO THE ENGINE-GENERATOR AFTER AN ADJUSTABLE TIME</p>			

SPECIAL TERMS & CONDITIONS		INVITATION TO BID	
NUMBER : 2238331 OPEN DATE: 02/25/10 TIME: 10:00 AM T-NUMBER : 92084		BIDDER:	PAGE 15
<p> DELAY OF AT LEAST 5 TO 180 SECONDS TO ALLOW GENERATOR SET TO REACH PROPER VOLTAGE AND FREQUENCY; FACTORY SET AT 5 SECONDS. </p> <p> RETRANSFER THE LOAD TO THE LINE AFTER NORMAL POWER RESTORATION. A TIME DELAY ON RETRANSFER ADJUSTABLE FROM 1 TO 30 MINUTES SHALL DELAY THIS TRANSFER TO AVOID SHORT TERM NORMAL POWER RESTORATION AND ALLOW IT TO CARRY LOAD FOR A SET PERIOD OF TIME. </p> <p> PROVIDE AN AUTOMATIC TRANSFER TIME DELAY BYPASS TO RETRANSFER THE LOAD FROM GENERATING SET TO NORMAL SOURCE IF THE GENERATING SET OUTPUT INTERRUPTS AFTER NORMAL SOURCE RESTORES VOLTAGE. </p> <p> SIGNAL THE ENGINE-GENERATOR TO STOP AFTER LOAD RETRANSFER TO NORMAL SOURCE. A SOLID STATE TIME DELAY STOP, ADJUSTABLE FROM AT LEAST 1 TO 10 MINUTES SHALL PERMIT ENGINE TO RUN UNLOADED TO PROPERLY COOL PRIOR TO SHUTDOWN. FACTORY SET AT 5 MINUTES. </p> <p> PROVIDE A KEYED TEST SWITCH OR MANUAL PROVISION TO SIMULATE AN INTERRUPTION OF POWER FROM NORMAL SOURCE. </p> <p> PROVIDE A SOLID STATE EXERCISER CLOCK TO AUTOMATICALLY START THE GENERATING SET AT REGULAR INTERVALS AND ALLOW IT TO RUN FOR A PRE-SET TIME PERIOD FOR EXERCISE PURPOSES. </p> <p> PROVIDE A WITH LOAD-WITHOUT LOAD SELECTOR SWITCH TO BE MOUNTED INSIDE OF CABINET TO SELECT TEST OR EXERCISE AS FOLLOWS: </p> <p> A) WITHOUT LOAD, THE GENERATING SET RUNS UNLOADED. </p> <p> B) WITH LOAD, THE AUTOMATIC TRANSFER SWITCH TRANSFERS THE LOAD TO GENERATING SET TIME DELAY, THE SAME AS IT WOULD FOR NORMAL SOURCE INTERRUPTION. </p> <p> PROVIDE A CONTROL DISCONNECT PLUS TO ELECTRICALLY DISCONNECT THE CONTROL SECTION FROM THE TRANSFER SWITCH FOR MAINTENANCE SERVICES DURING NORMAL OPERATION. </p> <p> LAMP COMBINATION: INDICATING LAMPS SHALL PROVIDE: NORMAL AND EMERGENCY INDICATING LAMPS FOR POWER AVAILABILITY. </p> <p> NORMAL AND EMERGENCY INDICATING LAMPS TO INDICATE WHICH SOURCE IS SUPPLYING POWER TO THE LOAD. </p> <p> FUEL TANK: DIESEL FUEL STORAGE SHALL BE DOUBLE WALL TYPE. TANK TO BE SANDBLASTED, PRIMED AND PAINTED. TANK SHALL HAVE FUEL LEVEL INDICATOR. FUEL LEAK WARNING INDICATOR. LOCKABLE FUEL FILL CAP. TANK TO BE UL LISTED. TANK SHALL BE SUB-BASE MOUNTED. </p> <p> MISCELLANEOUS </p> <p> GENERAL: SUCCESSFUL BIDDER SHALL PROVIDE OWNER'S OPERATING PERSONNEL WITH DETAILED OPERATION AND MAINTENANCE MANUALS INCLUDING COMPLETE PARTS LISTS. MANUALS SHALL INCLUDE ENGINE MANUFACTURER'S COMPLETE ENGINE MANUALS AS WELL AS MAJOR SERVICE MANUALS, ALTERNATOR OPERATION INSTRUCTIONS. FOUR (4) SETS OF MANUALS SHALL BE PROVIDED. (NOTE: IF SPECIAL TEST EQUIPMENT IS NEEDED TO CHECK GENERATOR OR TRANSFER </p>			

SPECIAL TERMS & CONDITIONS		INVITATION TO BID	
NUMBER : 2238331 OPEN DATE: 02/25/10 TIME: 10:00 AM T-NUMBER : 92084		BIDDER:	PAGE 16

SWITCH, IT MUST BE FURNISHED WITH BIT, FAST CHECK DIAGNOSTIC TESTER, ETC.

SERVICE: THESE FACILITIES SHALL COMPRISE A PERMANENT FORCE OF FACTORY TRAINED SERVICE PERSONNEL ON 24 HOUR CALL EXPERIENCED IN SERVICING THIS TYPE OF EQUIPMENT, PROVIDING WARRANTY AND/OR ROUTINE MAINTENANCE SERVICE TO AFFORD THE OWNER MAXIMUM PROTECTION.

WARRANTY: STANDBY ELECTRIC GENERATING SYSTEM COMPONENTS, COMPLETE ELECTRIC PLANT (ENGINE & ALTERNATOR) INSTRUMENT PANEL, AUTOMATIC TRANSFER SWITCH, REMOTE ALARM PANEL, SHALL BE WARRANTED BY THE MANUFACTURER AGAINST DEFECTIVE MATERIALS AND FACTORY WORKMANSHIP FOR A PERIOD OF FIVE YEARS OR 1500 HOURS, WHICHEVER OCCURS FIRST. SUCH DEFECTIVE PARTS SHALL BE REPAIRED OR REPLACED AT MANUFACTURER'S OPTION, FREE OF CHARGE FOR THIS PERIOD; ASSOCIATED LABOR, TRAVEL TIME AND MILEAGE SHALL ALSO BE PROVIDED FREE OF CHARGE FOR THE SAME PERIOD. THE WARRANTY PERIOD SHALL COMMENCE WHEN THE STANDBY POWER SYSTEM IS FIRST PLACED INTO SERVICE.

CHECK OUT & START UP: SUPPLIER OF THE ELECTRIC GENERATING PLANT AND ASSOCIATED ITEMS COVERED HEREIN SHALL PROVIDE FACTORY TRAINED TECHNICIANS TO CHECK OUT THE COMPLETED INSTALLATION AND PERFORM THE INITIAL STARTUP OF THE SYSTEM. THEY SHALL MEET WITH THE DEPARTMENT PERSONNEL TO DISCUSS THE INSTALLATION AND SHALL PROVIDE THE OWNER'S PERSONNEL WITH OPERATING AND MAINTENANCE INSTRUCTIONS AT THE TIME OF START UP.

LOAD BANK TESTING: AT THE TIME OF INITIAL START UP AND CHECK OUT OF THE STANDBY POWER SYSTEM BY THE SUPPLIER, THEY SHALL FURNISH LOAD BANKS AS REQUIRED WITH AN OPERATOR TO PERFORM THE FOLLOWING:

- 1) TEST SPEED AND VOLTAGE REGULATION FOR INSTANTANEOUS ON AND OFF LOAD CHANGES WITH LOADS OF 1/4, 1/2, 3/4 AND FULL LOAD RATING.
- 2) CONTINUOUS OPERATIONAL TEST AT FULL STABILIZER LOAD FOR UP TO FIVE HOURS WITH VOLTAGE, FREQUENCY, OIL PRESSURE AND ENGINE TEMPERATURE BEING RECORDED AT NO LOAD, BEGINNING OF TEST AND HOURLY THEREAFTER THRU DURATION.
- 3) AFTER THE ABOVE TESTS HAVE BEEN PERFORMED, RECONNECT THE GENERATOR TO THE BUILDING LOADS, TESTS COMPLETE SYSTEM FOR PROPER OPERATION WITH EMERGENCY LOADS.
- 4) ALL ELECTRICAL RECONNECTIONS ARE TO BE MADE BY THE SUPPLIER.

PAINT: MANUFACTURER'S COLORS ARE ACCEPTABLE.

SERVICES: READY FOR OPERATION.

DESCRIPTIVE LITERATURE: TWO (2) COPIES OF DESCRIPTIVE PRODUCT ADVERTISEMENT LITERATURE (BROCHURES) SHOULD BE FURNISHED WITH BID.

11 IF BIDDING OTHER THAN SPECIFIED, SUFFICIENT INFORMATION SHOULD BE ENCLOSED WITH THE BID IN ORDER TO DETERMINE QUALITY, SUITABILITY, AND COMPLIANCE WITH THE SPECIFICATIONS.

SPECIAL TERMS & CONDITIONS		INVITATION TO BID	
NUMBER : 2238331 OPEN DATE: 02/25/10 TIME: 10:00 AM T-NUMBER : 92084		BIDDER:	PAGE 17

FAILURE TO COMPLY WITH THIS REQUEST MAY ELIMINATE YOUR BID FROM CONSIDERATION.

12

SCOPE OF CONTRACT

SUBMITTAL OF ANY TERMS AND CONDITIONS CONTRARY TO THOSE OF THE STATE OF LOUISIANA MAY CAUSE YOUR BID TO BE REJECTED. BY SIGNING BELOW, TERMS AND CONDITIONS WHICH MAY BE INCLUDED IN YOUR BID ARE NULLIFIED, AND CONTRACTOR AGREES THAT THIS CONTRACT SHALL BE CONSTRUED IN ACCORDANCE WITH AND GOVERNED BY THE LAWS OF THE STATE OF LOUISIANA.

BIDDER SIGNATURE

13

COMPENSATION INSURANCE, PUBLIC LIABILITY, AND PROPERTY DAMAGE INSURANCE, AS OUTLINED BELOW, ARE REQUIRED IN THIS BID.

CONTRACTOR'S LIABILITY INSURANCE:

PROOF OF INSURANCE SHOULD BE SUPPLIED WITH THE BID AND WILL BE REQUIRED BEFORE WORK CAN COMMENCE.

INSURANCE COVERAGE SPECIFIED BELOW SHALL BE FURNISHED WITH THE FOLLOWING MINIMUM LIMITS:

COMPENSATION INSURANCE: THE CONTRACTOR AND SUBCONTRACTORS SHALL TAKE AND MAINTAIN DURING THE LIFE OF THE CONTRACT WORKMAN'S COMPENSATION INSURANCE FOR ALL OF THEIR EMPLOYEES EMPLOYED AT THE SITE OF THE PROJECT. IN CASE ANY CLASS OF EMPLOYEES ENGAGED IN HAZARDOUS WORK UNDER THE WORKMAN'S COMPENSATION STATUTE, THE CONTRACTOR AND SUBCONTRACTOR SHALL PROVIDE EMPLOYER'S LIABILITY INSURANCE FOR THE PROTECTION OF THEIR EMPLOYEES NOT OTHERWISE PROTECTED.

PUBLIC LIABILITY AND PROPERTY DAMAGE INSURANCE: COMPREHENSIVE PUBLIC GENERAL LIABILITY INSURANCE, INCLUDING BUT NOT LIMITED TO BODILY INJURY, PROPERTY DAMAGE, CONTRACTUAL LIABILITY, PRODUCTS LIABILITY, COMPLETED OPERATIONS AND OWNER'S PROTECTIVE LIABILITY WITH COMBINED SINGLE LIMITS OF \$500,000 PER OCCURRENCE WITH A MINIMUM AGGREGATE OF \$1,000,000.

LICENSED AND NON-LICENSED MOTOR VEHICLES: THE CONTRACTOR SHALL TAKE OUT AND MAINTAIN DURING THE LIFE OF THE CONTRACT, AUTOMOBILE PUBLIC LIABILITY INSURANCE IN AN AMOUNT NOT LESS THAN COMBINED SINGLE LIMITS OF \$500,000 PER OCCURRENCE FOR BODILY INJURY/PROPERTY DAMAGE. IF ANY NON-LICENSED MOTOR VEHICLES ARE ENGAGED IN OPERATIONS WITHIN THE TERMS OF THE CONTRACT ON THE SITE OF THE WORK TO PERFORM THEREUNDER, SUCH INSURANCE SHALL COVER THE USE OF ALL SUCH MOTOR VEHICLES ENGAGED IN OPERATING WITHIN THE TERMS OF THE CONTRACT ON THE SITE OF THE WORK TO BE PERFORMED THEREUNDER, UNLESS SUCH COVERAGE IS INCLUDED IN THE INSURANCE SPECIFIED.

14

THE ABOVE QUANTITIES ARE ESTIMATED TO BE THE AMOUNT NEEDED. IN THE

SPECIAL TERMS & CONDITIONS		INVITATION TO BID	
NUMBER : 2238331 OPEN DATE: 02/25/10 T-NUMBER : 92084		BIDDER:	PAGE 18
<p>EVENT A GREATER OR LESSER QUANTITY IS NEEDED, THE RIGHT IS RESERVED BY THE STATE OF LOUISIANA TO INCREASE OR DECREASE THE AMOUNT, AT THE UNIT PRICE STATED IN THE BID.</p>			
<p>15 AT THE OPTION OF THE STATE OF LOUISIANA AND ACCEPTANCE BY THE CONTRACTOR, THIS CONTRACT MAY BE EXTENDED FOR TWO ADDITIONAL TWELVE (12) MONTH PERIODS AT THE SAME PRICE, TERMS AND CONDITIONS. TOTAL CONTRACT TIME MAY NOT EXCEED THIRTY-SIX (36) MONTHS.</p> <p>CONTRACTUAL PERIOD. THE STATE OF LOUISIANA INTENDS TO AWARD ALL ITEMS FOR AN INITIAL PERIOD, NOT TO EXCEED 12 MONTHS. DELAYS IN AWARDED, BEYOND THE ANTICIPATED STARTING DATE, MAY RESULT IN A CHANGE IN THE CONTRACT PERIOD. IF THE SITUATION OCCURS, AN AWARD MAY BE MADE FOR LESS THAN 12 MONTHS.</p> <p>CERTIFICATION OF NO SUSPENSION OR DEBARMENT. BY SIGNING AND SUBMITTING ANY BID FOR \$100,000 OR MORE, THE BIDDER CERTIFIES THAT THEIR COMPANY, ANY SUBCONTRACTORS, OR PRINCIPALS ARE NOT SUSPENDED OR DEBARRED BY THE GENERAL SERVICES ADMINISTRATION (GSA) IN ACCORDANCE WITH THE REQUIREMENTS IN OMB CIRCULAR A-133.</p> <p>A LIST OF PARTIES WHO HAVE BEEN SUSPENDED OR DEBARRED CAN BE VIEWED VIA THE INTERNET AT WWW.EPLS.GOV</p>			
<p>16 AWARD OF CONTRACT: IT IS THE STATE OF LOUISIANA'S INTENTION TO AWARD THIS CONTRACT ON A GROUPED BASIS AS LISTED BELOW. LINES 1-5, 6-10, 11-15, 16-20, 21-25, 26-30, 31-35, 36-40, 41-45, 46-50, 51-55, 56-60, 61-65, 66-70, 71-75, 76-80, 81-85, 86-90, 91-95, 96-99, 100-103, 104-107, 108-111, 112-115, 116-119, 120-123, 124-127, 128-131, AND 132-135.</p>			
<p>17 ***** NOTE IF THERE ARE ANY SPECIFICATIONS THAT MIGHT PREVENT YOU FROM BIDDING DUE TO MANDATORY OR DUE TO MINIMUM/MAXIMUM REQUIREMENTS YOU SHOULD CONTACT ROB HAYNES AT (225) 342-8035 OR BY EMAIL TO ROB.HAYNES@LA.GOV IMMEDIATELY BUT NO LATER THAN SEVEN (7) DAYS PRIOR TO BID BID OPENING. *****</p>			
<p>18 SUCCESSFUL VENDOR IS TO KEEP A RECORD OF ALL ORDERS ISSUED AGAINST THIS CONTRACT DURING THE CONTRACT PERIOD. APPROXIMATELY FOUR (4) MONTHS PRIOR TO THE END OF THE CONTRACT PERIOD, THE VENDOR IS TO BE PREPARED TO SUBMIT TO THE OFFICE OF STATE PURCHASING A CONTRACT USAGE REPORT.</p> <p>THE USAGE REPORT IS TO INCLUDE THE VENDOR'S NAME, PHONE AND FAX NUMBERS, THE PERSONS WHO COMPILED THE REPORT AND A SUMMARY "BY LINE ITEM" INDICATING QUANTITY PURCHASED.</p>			

PRICE SHEET		INVITATION TO BID			
NUMBER : 2238331 OPEN DATE : 02/25/10 TIME: 10:00 AM T-NUMBER : 92084		BIDDER:			PAGE 19
LINE NO.	COMMODITY/SERVICE DESCRIPTION	QUANTITY FROM/TO	UNIT	UNIT PRICE	EXTENDED TOTAL
	UNLESS SPECIFIED ELSEWHERE SHIP TO: STATEWIDE DELIVERY				
00001	COMMODITY CODE: 285-39-120826 GENERATOR, STATIONARY, 10 KW, 1-PHASE, 60 HZ, DIESEL FUELED, WITH AUTOMATIC TRANSFER SWITCH, NO FUEL SUPPLY. CONNECTED FOR 1-PHASE, 3 WIRE 120/240 VOLTS. 12 LEAD RECONNECTABLE LEAD CONNECTION. TRANSFER SWITCH SHOULD BE RATED AT NO LESS THAN 100 AMPS CONTINUOUS, AT 1-PHASE, 3 WIRE, 120/240 VOLTS. STATIONARY GENERATOR SYSTEM SHALL INCLUDE A 5 YEAR OR 1500 HOUR PARTS AND LABOR WARRANTY TO BEGIN WHEN SYSTEM IS FIRST PLACED IN SERVICE. STATE ATS MODEL NUMBER: _____ SPECIFY BRAND (& NUMBER IF APPLICABLE) _____	1	EACH		
00002	COMMODITY CODE: 285-39-120826 FUEL STORAGE TANK: A SUB-BASE, DOUBLE WALL TYPE, DIESEL FUEL STORAGE TANK WITH A MINIMUM OF 120 GALLONS CAPACITY. FOR GENERATOR ON LINE 1. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____	1	EACH		
00003	COMMODITY CODE: 285-39-120826 REMOTE ANNUNCIATOR: 12 OR 24 VOLT, NFPA 110 COMPLIANT	1	EACH		

PRICE SHEET		INVITATION TO BID			
NUMBER : 2238331 OPEN DATE : 02/25/10 TIME: 10:00 AM T-NUMBER : 92084		BIDDER:			PAGE 20
LINE NO.	COMMODITY/SERVICE DESCRIPTION	QUANTITY FROM/TO	UNIT	UNIT PRICE	EXTENDED TOTAL
	FOR GENERATOR ON LINE 1. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____				
00004	COMMODITY CODE: 285-39-120826 ENCLOSURE: WEATHER PROTECTIVE FOR GENERATOR ON LINE 1. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____	1	EACH	_____	_____
00005	COMMODITY CODE: 285-39-120826 ENCLOSURE: SOUND ATTENUATED THE ENCLOSURE SHALL REDUCE THE GENERATOR SOUND LEVEL TO NO MORE THAN 76 DBA. ENCLOSURE SHALL BE WEATHER PROTECTIVE. FOR GENERATOR ON LINE 1. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____	1	EACH	_____	_____
00006	COMMODITY CODE: 285-39-120826 GENERATOR, STATIONARY, 10 KW, 3-PHASE, 60 HZ, DIESEL FUELED, WITH AUTOMATIC TRANSFER SWITCH, NO FUEL SUPPLY. CONNECTED FOR 3-PHASE, 4 WIRE 120/240 VOLTS. 12 LEAD RECONNECTABLE LEAD CONNECTION. TRANSFER SWITCH SHOULD BE RATED AT NO LESS THAN 100 AMPS CONTINUOUS, AT 3-PHASE, 4 WIRE, 120/240 VOLTS. STATIONARY GENERATOR SYSTEM SHALL	1	EACH	_____	_____

PRICE SHEET		INVITATION TO BID			
NUMBER : 2238331 OPEN DATE : 02/25/10 TIME: 10:00 AM T-NUMBER : 92084		BIDDER:			PAGE 21
LINE NO.	COMMODITY/SERVICE DESCRIPTION	QUANTITY FROM/TO	UNIT	UNIT PRICE	EXTENDED TOTAL
	INCLUDE A 5 YEAR OR 1500 HOUR PARTS AND LABOR WARRANTY TO BEGIN WHEN SYSTEM IS FIRST PLACED IN SERVICE. STATE ATS MODEL NUMBER: _____ SPECIFY BRAND (& NUMBER IF APPLICABLE) _____				
00007	COMMODITY CODE: 285-39-120826 FUEL STORAGE TANK: A SUB-BASE, DOUBLE WALL TYPE, DIESEL FUEL STORAGE TANK WITH A MINIMUM OF 120 GALLONS CAPACITY. FOR GENERATOR ON LINE 6. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____	1	EACH	_____	_____
00008	COMMODITY CODE: 285-39-120826 REMOTE ANNUNCIATOR: 12 OR 24 VOLT, NFPA 110 COMPLIANT FOR GENERATOR ON LINE 6. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____	1	EACH	_____	_____
00009	COMMODITY CODE: 285-39-120826 ENCLOSURE: WEATHER PROTECTIVE FOR GENERATOR ON LINE 6. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____	1	EACH	_____	_____

PRICE SHEET		INVITATION TO BID			
NUMBER : 2238331 OPEN DATE : 02/25/10 TIME: 10:00 AM T-NUMBER : 92084		BIDDER:			PAGE 22
LINE NO.	COMMODITY/SERVICE DESCRIPTION	QUANTITY FROM/TO	UNIT	UNIT PRICE	EXTENDED TOTAL
00010	COMMODITY CODE: 285-39-120826 ENCLOSURE: SOUND ATTENUATED THE ENCLOSURE SHALL REDUCE THE GENERATOR SOUND LEVEL TO NO MORE THAN 76 DBA. ENCLOSURE SHALL BE WEATHER PROTECTIVE. FOR GENERATOR ON LINE 6. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____	1	EACH	_____	_____
00011	COMMODITY CODE: 285-39-120826 GENERATOR, STATIONARY, 20 KW, 1-PHASE, 60 HZ, DIESEL FUELED, WITH AUTOMATIC TRANSFER SWITCH, NO FUEL SUPPLY. CONNECTED FOR 1-PHASE, 3 WIRE 120/240 VOLTS. 12 LEAD RECONNECTABLE LEAD CONNECTION. TRANSFER SWITCH SHOULD BE RATED AT NO LESS THAN 200 AMPS CONTINUOUS, AT 1-PHASE, 3 WIRE, 120/240 VOLTS. STATIONARY GENERATOR SYSTEM SHALL INCLUDE A 5 YEAR OR 1500 HOUR PARTS AND LABOR WARRANTY TO BEGIN WHEN SYSTEM IS FIRST PLACED IN SERVICE. STATE ATS MODEL NUMBER: _____ SPECIFY BRAND (& NUMBER IF APPLICABLE) _____	1	EACH	_____	_____
00012	COMMODITY CODE: 285-39-120826 FUEL STORAGE TANK: A SUB-BASE, DOUBLE WALL TYPE, DIESEL FUEL STORAGE TANK WITH A MINIMUM OF 120 GALLONS CAPACITY. FOR GENERATOR ON LINE 11.	1	EACH	_____	_____

PRICE SHEET		INVITATION TO BID			
NUMBER : 2238331 OPEN DATE : 02/25/10 TIME: 10:00 AM T-NUMBER : 92084		BIDDER:			PAGE 23
LINE NO.	COMMODITY/SERVICE DESCRIPTION	QUANTITY FROM/TO	UNIT	UNIT PRICE	EXTENDED TOTAL
_____	SPECIFY BRAND (& NUMBER IF APPLICABLE) _____				
00013	COMMODITY CODE: 285-39-120826 REMOTE ANNUNCIATOR: 12 OR 24 VOLT, NFPA 110 COMPLIANT FOR GENERATOR ON LINE 11. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____	1	EACH	_____	_____
00014	COMMODITY CODE: 285-39-120826 ENCLOSURE: WEATHER PROTECTIVE FOR GENERATOR ON LINE 11. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____	1	EACH	_____	_____
00015	COMMODITY CODE: 285-39-120826 ENCLOSURE: SOUND ATTENUATED THE ENCLOSURE SHALL REDUCE THE GENERATOR SOUND LEVEL TO NO MORE THAN 76 DBA. ENCLOSURE SHALL BE WEATHER PROTECTIVE. FOR GENERATOR ON LINE 11 SPECIFY BRAND (& NUMBER IF APPLICABLE) _____	1	EACH	_____	_____
00016	COMMODITY CODE: 285-39-120826	1	EACH	_____	_____

PRICE SHEET		INVITATION TO BID			
NUMBER : 2238331 OPEN DATE : 02/25/10 TIME: 10:00 AM T-NUMBER : 92084		BIDDER:			PAGE 24
LINE NO.	COMMODITY/SERVICE DESCRIPTION	QUANTITY FROM/TO	UNIT	UNIT PRICE	EXTENDED TOTAL
	GENERATOR, STATIONARY, 20 KW, 3-PHASE, 60 HZ, DIESEL FUELED, WITH AUTOMATIC TRANSFER SWITCH, NO FUEL SUPPLY. CONNECTED FOR 3-PHASE, 4 WIRE 120/240 VOLTS. 12 LEAD RECONNECTABLE LEAD CONNECTION. TRANSFER SWITCH SHOULD BE RATED AT NO LESS THAN 200 AMPS CONTINUOUS, AT 3-PHASE, 4 WIRE, 120/240 VOLTS. STATIONARY GENERATOR SYSTEM SHALL INCLUDE A 5 YEAR OR 1500 HOUR PARTS AND LABOR WARRANTY TO BEGIN WHEN SYSTEM IS FIRST PLACED IN SERVICE. STATE ATS MODEL NUMBER: _____ SPECIFY BRAND (& NUMBER IF APPLICABLE) _____				
00017	COMMODITY CODE: 285-39-120826 FUEL STORAGE TANK: A SUB-BASE, DOUBLE WALL TYPE, DIESEL FUEL STORAGE TANK WITH A MINIMUM OF 120 GALLONS CAPACITY. FOR GENERATOR ON LINE 16. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____	1	EACH	_____	_____
00018	COMMODITY CODE: 285-39-120826 REMOTE ANNUNCIATOR: 12 OR 24 VOLT, NFPA 110 COMPLIANT FOR GENERATOR ON LINE 16. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____	1	EACH	_____	_____

PRICE SHEET		INVITATION TO BID			
NUMBER : 2238331 OPEN DATE : 02/25/10 TIME: 10:00 AM T-NUMBER : 92084		BIDDER:			PAGE 25
LINE NO.	COMMODITY/SERVICE DESCRIPTION	QUANTITY FROM/TO	UNIT	UNIT PRICE	EXTENDED TOTAL
00019	COMMODITY CODE: 285-39-120826 ENCLOSURE: WEATHER PROTECTIVE FOR GENERATOR ON LINE 16. SPECIFY BRAND (& NUMBER IF APPLICABLE)	1	EACH		
00020	COMMODITY CODE: 285-39-120826 ENCLOSURE: SOUND ATTENUATED THE ENCLOSURE SHALL REDUCE THE GENERATOR SOUND LEVEL TO NO MORE THAN 76 DBA. ENCLOSURE SHALL BE WEATHER PROTECTIVE. FOR GENERATOR ON LINE 16. SPECIFY BRAND (& NUMBER IF APPLICABLE)	1	EACH		
00021	COMMODITY CODE: 285-39-120826 GENERATOR, STATIONARY, 30 KW, 1-PHASE, 60 HZ, DIESEL FUELED, WITH AUTOMATIC TRANSFER SWITCH, NO FUEL SUPPLY. CONNECTED FOR 1-PHASE, 3 WIRE 120/240 VOLTS. 12 LEAD RECONNECTABLE LEAD CONNECTION. TRANSFER SWITCH SHOULD BE RATED AT NO LESS THAN 200 AMPS CONTINUOUS, AT 1-PHASE, 3 WIRE, 120/240 VOLTS. STATIONARY GENERATOR SYSTEM SHALL INCLUDE A 5 YEAR OR 1500 HOUR PARTS AND LABOR WARRANTY TO BEGIN WHEN SYSTEM IS FIRST PLACED IN SERVICE. STATE ATS MODEL NUMBER: _____ SPECIFY BRAND (& NUMBER IF	1	EACH		

PRICE SHEET		INVITATION TO BID			
NUMBER : 2238331 OPEN DATE : 02/25/10 TIME: 10:00 AM T-NUMBER : 92084		BIDDER:			PAGE 26
LINE NO.	COMMODITY/SERVICE DESCRIPTION	QUANTITY FROM/TO	UNIT	UNIT PRICE	EXTENDED TOTAL
	APPLICABLE)				
00022	COMMODITY CODE: 285-39-120826 FUEL STORAGE TANK: A SUB-BASE, DOUBLE WALL TYPE, DIESEL FUEL STORAGE TANK WITH A MINIMUM OF 120 GALLONS CAPACITY. FOR GENERATOR ON LINE 21. SPECIFY BRAND (& NUMBER IF APPLICABLE)	1	EACH		
00023	COMMODITY CODE: 285-39-120826 REMOTE ANNUNCIATOR: 12 OR 24 VOLT, NFPA 110 COMPLIANT FOR GENERATOR ON LINE 21. SPECIFY BRAND (& NUMBER IF APPLICABLE)	1	EACH		
00024	COMMODITY CODE: 285-39-120826 ENCLOSURE: WEATHER PROTECTIVE FOR GENERATOR ON LINE 21. SPECIFY BRAND (& NUMBER IF APPLICABLE)	1	EACH		
00025	COMMODITY CODE: 285-39-120826 ENCLOSURE: SOUND ATTENUATED THE ENCLOSURE SHALL REDUCE THE GENERATOR SOUND LEVEL TO NO MORE THAN 76 DBA.	1	EACH		

PRICE SHEET		INVITATION TO BID			
NUMBER : 2238331 OPEN DATE : 02/25/10 TIME: 10:00 AM T-NUMBER : 92084		BIDDER:			PAGE 27
LINE NO.	COMMODITY/SERVICE DESCRIPTION	QUANTITY FROM/TO	UNIT	UNIT PRICE	EXTENDED TOTAL
00026	ENCLOSURE SHALL BE WEATHER PROTECTIVE. FOR GENERATOR ON LINE 21. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____ COMMODITY CODE: 285-39-120826 GENERATOR, STATIONARY, 30 KW, 3-PHASE, 60 HZ, DIESEL FUELED, WITH AUTOMATIC TRANSFER SWITCH, NO FUEL SUPPLY. CONNECTED FOR 3-PHASE, 4 WIRE 120/240 VOLTS. 12 LEAD RECONNECTABLE LEAD CONNECTION. TRANSFER SWITCH SHOULD BE RATED AT NO LESS THAN 200 AMPS CONTINUOUS, AT 3-PHASE, 4 WIRE, 120/240 VOLTS. STATIONARY GENERATOR SYSTEM SHALL INCLUDE A 5 YEAR OR 1500 HOUR PARTS AND LABOR WARRANTY TO BEGIN WHEN SYSTEM IS FIRST PLACED IN SERVICE. STATE ATS MODEL NUMBER: _____ SPECIFY BRAND (& NUMBER IF APPLICABLE) _____	1	EACH	_____	_____
00027	COMMODITY CODE: 285-39-120826 FUEL STORAGE TANK: A SUB-BASE, DOUBLE WALL TYPE, DIESEL FUEL STORAGE TANK WITH A MINIMUM OF 120 GALLONS CAPACITY. FOR GENERATOR ON LINE 26. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____	1	EACH	_____	_____
00028	COMMODITY CODE: 285-39-120826	1	EACH	_____	_____

PRICE SHEET		INVITATION TO BID			
NUMBER : 2238331 OPEN DATE : 02/25/10 TIME: 10:00 AM T-NUMBER : 92084		BIDDER:			PAGE 28
LINE NO.	COMMODITY/SERVICE DESCRIPTION	QUANTITY FROM/TO	UNIT	UNIT PRICE	EXTENDED TOTAL
	REMOTE ANNUNCIATOR: 12 OR 24 VOLT, NFPA 110 COMPLIANT FOR GENERATOR ON LINE 26. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____				
00029	COMMODITY CODE: 285-39-120826 ENCLOSURE: WEATHER PROTECTIVE FOR GENERATOR ON LINE 26. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____	1	EACH	_____	_____
00030	COMMODITY CODE: 285-39-120826 ENCLOSURE: SOUND ATTENUATED THE ENCLOSURE SHALL REDUCE THE GENERATOR SOUND LEVEL TO NO MORE THAN 76 DBA. ENCLOSURE SHALL BE WEATHER PROTECTIVE. FOR GENERATOR ON LINE 26. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____	1	EACH	_____	_____
00031	COMMODITY CODE: 285-39-120826 GENERATOR, STATIONARY, 40 KW, 1-PHASE, 60 HZ, DIESEL FUELED, WITH AUTOMATIC TRANSFER SWITCH, NO FUEL SUPPLY. CONNECTED FOR 1-PHASE, 3 WIRE 120/240 VOLTS. 12 LEAD RECONNECTABLE LEAD CONNECTION. TRANSFER SWITCH SHOULD BE RATED AT NO LESS THAN 200 AMPS CONTINUOUS, AT 1-PHASE, 3 WIRE, 120/240 VOLTS.	1	EACH	_____	_____

PRICE SHEET		INVITATION TO BID			
NUMBER : 2238331 OPEN DATE : 02/25/10 TIME: 10:00 AM T-NUMBER : 92084		BIDDER:			PAGE 29
LINE NO.	COMMODITY/SERVICE DESCRIPTION	QUANTITY FROM/TO	UNIT	UNIT PRICE	EXTENDED TOTAL
00032	STATIONARY GENERATOR SYSTEM SHALL INCLUDE A 5 YEAR OR 1500 HOUR PARTS AND LABOR WARRANTY TO BEGIN WHEN SYSTEM IS FIRST PLACED IN SERVICE. STATE ATS MODEL NUMBER: _____ SPECIFY BRAND (& NUMBER IF APPLICABLE) _____ COMMODITY CODE: 285-39-120826 FUEL STORAGE TANK: A SUB-BASE, DOUBLE WALL TYPE, DIESEL FUEL STORAGE TANK WITH A MINIMUM OF 120 GALLONS CAPACITY. FOR GENERATOR ON LINE 31. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____	1	EACH	_____	_____
00033	COMMODITY CODE: 285-39-120826 REMOTE ANNUNCIATOR: 12 OR 24 VOLT, NFPA 110 COMPLIANT FOR GENERATOR ON LINE 31. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____	1	EACH	_____	_____
00034	COMMODITY CODE: 285-39-120826 ENCLOSURE: WEATHER PROTECTIVE FOR GENERATOR ON LINE 31. SPECIFY BRAND (& NUMBER IF APPLICABLE)	1	EACH	_____	_____

PRICE SHEET		INVITATION TO BID			
NUMBER : 2238331 OPEN DATE : 02/25/10 TIME: 10:00 AM T-NUMBER : 92084		BIDDER:			PAGE 30
LINE NO.	COMMODITY/SERVICE DESCRIPTION	QUANTITY FROM/TO	UNIT	UNIT PRICE	EXTENDED TOTAL
00035	COMMODITY CODE: 285-39-120826 ENCLOSURE: SOUND ATTENUATED THE ENCLOSURE SHALL REDUCE THE GENERATOR SOUND LEVEL TO NO MORE THAN 76 DBA. ENCLOSURE SHALL BE WEATHER PROTECTIVE. FOR GENERATOR ON LINE 31. SPECIFY BRAND (& NUMBER IF APPLICABLE)	1	EACH		
00036	COMMODITY CODE: 285-39-120826 GENERATOR, STATIONARY, 40 KW, 3-PHASE, 60 HZ, DIESEL FUELED, WITH AUTOMATIC TRANSFER SWITCH, NO FUEL SUPPLY. CONNECTED FOR 3-PHASE, 4 WIRE 120/240 VOLTS. 12 LEAD RECONNECTABLE LEAD CONNECTION. TRANSFER SWITCH SHOULD BE RATED AT NO LESS THAN 200 AMPS CONTINUOUS, AT 3-PHASE, 4 WIRE, 120/240 VOLTS. STATIONARY GENERATOR SYSTEM SHALL INCLUDE A 5 YEAR OR 1500 HOUR PARTS AND LABOR WARRANTY TO BEGIN WHEN SYSTEM IS FIRST PLACED IN SERVICE. STATE ATS MODEL NUMBER: _____ SPECIFY BRAND (& NUMBER IF APPLICABLE)	1	EACH		
00037	COMMODITY CODE: 285-39-120826 FUEL STORAGE TANK: A SUB-BASE, DOUBLE WALL TYPE, DIESEL FUEL STORAGE TANK WITH	1	EACH		

PRICE SHEET		INVITATION TO BID			
NUMBER : 2238331 OPEN DATE : 02/25/10 TIME: 10:00 AM T-NUMBER : 92084		BIDDER:			PAGE 31
LINE NO.	COMMODITY/SERVICE DESCRIPTION	QUANTITY FROM/TO	UNIT	UNIT PRICE	EXTENDED TOTAL
	A MINIMUM OF 120 GALLONS CAPACITY. FOR GENERATOR ON LINE 36. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____				
00038	COMMODITY CODE: 285-39-120826 REMOTE ANNUNCIATOR: 12 OR 24 VOLT, NFPA 110 COMPLIANT FOR GENERATOR ON LINE 36. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____	1	EACH	_____	_____
00039	COMMODITY CODE: 285-39-120826 ENCLOSURE: WEATHER PROTECTIVE FOR GENERATOR ON LINE 36. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____	1	EACH	_____	_____
00040	COMMODITY CODE: 285-39-120826 ENCLOSURE: SOUND ATTENUATED THE ENCLOSURE SHALL REDUCE THE GENERATOR SOUND LEVEL TO NO MORE THAN 76 DBA. ENCLOSURE SHALL BE WEATHER PROTECTIVE. FOR GENERATOR ON LINE 36. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____	1	EACH	_____	_____
00041	COMMODITY CODE: 285-39-120826	1	EACH	_____	_____

PRICE SHEET		INVITATION TO BID			
NUMBER : 2238331 OPEN DATE : 02/25/10 TIME: 10:00 AM T-NUMBER : 92084		BIDDER:			PAGE 32
LINE NO.	COMMODITY/SERVICE DESCRIPTION	QUANTITY FROM/TO	UNIT	UNIT PRICE	EXTENDED TOTAL
	GENERATOR, STATIONARY, 50 KW, 1-PHASE, 60 HZ, DIESEL FUELED, WITH AUTOMATIC TRANSFER SWITCH, NO FUEL SUPPLY. CONNECTED FOR 1-PHASE, 3 WIRE 120/240 VOLTS. 12 LEAD RECONNECTABLE LEAD CONNECTION. TRANSFER SWITCH SHOULD BE RATED AT NO LESS THAN 300 AMPS CONTINUOUS, AT 1-PHASE, 3 WIRE, 120/240 VOLTS. STATIONARY GENERATOR SYSTEM SHALL INCLUDE A 5 YEAR OR 1500 HOUR PARTS AND LABOR WARRANTY TO BEGIN WHEN SYSTEM IS FIRST PLACED IN SERVICE. STATE ATS MODEL NUMBER: _____ SPECIFY BRAND (& NUMBER IF APPLICABLE) _____				
00042	COMMODITY CODE: 285-39-120826 FUEL STORAGE TANK: A SUB-BASE, DOUBLE WALL TYPE, DIESEL FUEL STORAGE TANK WITH A MINIMUM OF 120 GALLONS CAPACITY. FOR GENERATOR ON LINE 41. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____	1	EACH	_____	_____
00043	COMMODITY CODE: 285-39-120826 REMOTE ANNUNCIATOR: 12 OR 24 VOLT, NFPA 110 COMPLIANT FOR GENERATOR ON LINE 41. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____	1	EACH	_____	_____

PRICE SHEET		INVITATION TO BID			
NUMBER : 2238331 OPEN DATE : 02/25/10 TIME: 10:00 AM T-NUMBER : 92084		BIDDER:			PAGE 33
LINE NO.	COMMODITY/SERVICE DESCRIPTION	QUANTITY FROM/TO	UNIT	UNIT PRICE	EXTENDED TOTAL
00044	COMMODITY CODE: 285-39-120826 ENCLOSURE: WEATHER PROTECTIVE FOR GENERATOR ON LINE 41. SPECIFY BRAND (& NUMBER IF APPLICABLE)	1	EACH		
00045	COMMODITY CODE: 285-39-120826 ENCLOSURE: SOUND ATTENUATED THE ENCLOSURE SHALL REDUCE THE GENERATOR SOUND LEVEL TO NO MORE THAN 76 DBA. ENCLOSURE SHALL BE WEATHER PROTECTIVE. FOR GENERATOR ON LINE 41. SPECIFY BRAND (& NUMBER IF APPLICABLE)	1	EACH		
00046	COMMODITY CODE: 285-39-120826 GENERATOR, STATIONARY, 50 KW, 3-PHASE, 60 HZ, DIESEL FUELED, WITH AUTOMATIC TRANSFER SWITCH, NO FUEL SUPPLY. CONNECTED FOR 3-PHASE, 4 WIRE 120/240 VOLTS. 12 LEAD RECONNECTABLE LEAD CONNECTION. TRANSFER SWITCH SHOULD BE RATED AT NO LESS THAN 300 AMPS CONTINUOUS, AT 3-PHASE, 4 WIRE, 120/240 VOLTS. STATIONARY GENERATOR SYSTEM SHALL INCLUDE A 5 YEAR OR 1500 HOUR PARTS AND LABOR WARRANTY TO BEGIN WHEN SYSTEM IS FIRST PLACED IN SERVICE. STATE ATS MODEL NUMBER: _____ SPECIFY BRAND (& NUMBER IF	1	EACH		

PRICE SHEET		INVITATION TO BID			
NUMBER : 2238331 OPEN DATE : 02/25/10 TIME: 10:00 AM T-NUMBER : 92084		BIDDER:			PAGE 34
LINE NO.	COMMODITY/SERVICE DESCRIPTION	QUANTITY FROM/TO	UNIT	UNIT PRICE	EXTENDED TOTAL
	APPLICABLE)				
00047	COMMODITY CODE: 285-39-120826 FUEL STORAGE TANK: A SUB-BASE, DOUBLE WALL TYPE, DIESEL FUEL STORAGE TANK WITH A MINIMUM OF 120 GALLONS CAPACITY. FOR GENERATOR ON LINE 46. SPECIFY BRAND (& NUMBER IF APPLICABLE)	1	EACH		
00048	COMMODITY CODE: 285-39-120826 REMOTE ANNUNCIATOR: 12 OR 24 VOLT, NFPA 110 COMPLIANT FOR GENERATOR ON LINE 46. SPECIFY BRAND (& NUMBER IF APPLICABLE)	1	EACH		
00049	COMMODITY CODE: 285-39-120826 ENCLOSURE: WEATHER PROTECTIVE FOR GENERATOR ON LINE 46. SPECIFY BRAND (& NUMBER IF APPLICABLE)	1	EACH		
00050	COMMODITY CODE: 285-39-120826 ENCLOSURE: SOUND ATTENUATED THE ENCLOSURE SHALL REDUCE THE GENERATOR SOUND LEVEL TO NO MORE THAN 76 DBA.	1	EACH		

PRICE SHEET		INVITATION TO BID			
NUMBER : 2238331 OPEN DATE : 02/25/10 TIME: 10:00 AM T-NUMBER : 92084		BIDDER:			PAGE 35
LINE NO.	COMMODITY/SERVICE DESCRIPTION	QUANTITY FROM/TO	UNIT	UNIT PRICE	EXTENDED TOTAL
00051	<p>ENCLOSURE SHALL BE WEATHER PROTECTIVE. FOR GENERATOR ON LINE 46.</p> <p>SPECIFY BRAND (& NUMBER IF APPLICABLE)</p> <p>_____</p> <p>COMMODITY CODE: 285-39-120826</p> <p>GENERATOR, STATIONARY, 100 KW, 1-PHASE, 60 HZ, DIESEL FUELED, WITH AUTOMATIC TRANSFER SWITCH, NO FUEL SUPPLY. CONNECTED FOR 1-PHASE, 3 WIRE 120/240 VOLTS. 12 LEAD RECONNECTABLE LEAD CONNECTION.</p> <p>TRANSFER SWITCH SHOULD BE RATED AT NO LESS THAN 600 AMPS CONTINUOUS, AT 1-PHASE, 3 WIRE, 120/240 VOLTS.</p> <p>STATIONARY GENERATOR SYSTEM SHALL INCLUDE A 5 YEAR OR 1500 HOUR PARTS AND LABOR WARRANTY TO BEGIN WHEN SYSTEM IS FIRST PLACED IN SERVICE.</p> <p>STATE ATS MODEL NUMBER: _____</p> <p>SPECIFY BRAND (& NUMBER IF APPLICABLE)</p> <p>_____</p>	1	EACH	_____	_____
00052	<p>COMMODITY CODE: 285-39-120826</p> <p>FUEL STORAGE TANK: A SUB-BASE, DOUBLE WALL TYPE, DIESEL FUEL STORAGE TANK WITH A MINIMUM OF 180 GALLONS CAPACITY. FOR GENERATOR ON LINE 51.</p> <p>SPECIFY BRAND (& NUMBER IF APPLICABLE)</p> <p>_____</p>	1	EACH	_____	_____
00053	<p>COMMODITY CODE: 285-39-120826</p>	1	EACH	_____	_____

PRICE SHEET		INVITATION TO BID			
NUMBER : 2238331 OPEN DATE : 02/25/10 TIME: 10:00 AM T-NUMBER : 92084		BIDDER:			PAGE 36
LINE NO.	COMMODITY/SERVICE DESCRIPTION	QUANTITY FROM/TO	UNIT	UNIT PRICE	EXTENDED TOTAL
	REMOTE ANNUNCIATOR: 12 OR 24 VOLT, NFPA 110 COMPLIANT FOR GENERATOR ON LINE 51. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____				
00054	COMMODITY CODE: 285-39-120826 ENCLOSURE: WEATHER PROTECTIVE FOR GENERATOR ON LINE 51. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____	1	EACH	_____	_____
00055	COMMODITY CODE: 285-39-120826 ENCLOSURE: SOUND ATTENUATED THE ENCLOSURE SHALL REDUCE THE GENERATOR SOUND LEVEL TO NO MORE THAN 76 DBA. ENCLOSURE SHALL BE WEATHER PROTECTIVE. FOR GENERATOR ON LINE 51. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____	1	EACH	_____	_____
00056	COMMODITY CODE: 285-39-120826 GENERATOR, STATIONARY, 100 KW, 3-PHASE, 60 HZ, DIESEL FUELED, WITH AUTOMATIC TRANSFER SWITCH, NO FUEL SUPPLY. CONNECTED FOR 3-PHASE, 4 WIRE 120/240 VOLTS. 12 LEAD RECONNECTABLE LEAD CONNECTION. TRANSFER SWITCH SHOULD BE RATED AT NO LESS THAN 400 AMPS CONTINUOUS, AT 3-PHASE, 4 WIRE, 120/240 VOLTS.	1	EACH	_____	_____

PRICE SHEET		INVITATION TO BID			
NUMBER : 2238331 OPEN DATE : 02/25/10 TIME: 10:00 AM T-NUMBER : 92084		BIDDER:			PAGE 37
LINE NO.	COMMODITY/SERVICE DESCRIPTION	QUANTITY FROM/TO	UNIT	UNIT PRICE	EXTENDED TOTAL
	STATIONARY GENERATOR SYSTEM SHALL INCLUDE A 5 YEAR OR 1500 HOUR PARTS AND LABOR WARRANTY TO BEGIN WHEN SYSTEM IS FIRST PLACED IN SERVICE. STATE ATS MODEL NUMBER: _____ SPECIFY BRAND (& NUMBER IF APPLICABLE) _____				
00057	COMMODITY CODE: 285-39-120826 FUEL STORAGE TANK: A SUB-BASE, DOUBLE WALL TYPE, DIESEL FUEL STORAGE TANK WITH A MINIMUM OF 180 GALLONS CAPACITY. FOR GENERATOR ON LINE 56. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____	1	EACH	_____	_____
00058	COMMODITY CODE: 285-39-120826 REMOTE ANNUNCIATOR: 12 OR 24 VOLT, NFPA 110 COMPLIANT FOR GENERATOR ON LINE 56. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____	1	EACH	_____	_____
00059	COMMODITY CODE: 285-39-120826 ENCLOSURE: WEATHER PROTECTIVE FOR GENERATOR ON LINE 56. SPECIFY BRAND (& NUMBER IF APPLICABLE)	1	EACH	_____	_____

PRICE SHEET		INVITATION TO BID			
NUMBER : 2238331 OPEN DATE : 02/25/10 TIME: 10:00 AM T-NUMBER : 92084		BIDDER:			PAGE 38
LINE NO.	COMMODITY/SERVICE DESCRIPTION	QUANTITY FROM/TO	UNIT	UNIT PRICE	EXTENDED TOTAL
00060	COMMODITY CODE: 285-39-120826 ENCLOSURE: SOUND ATTENUATED THE ENCLOSURE SHALL REDUCE THE GENERATOR SOUND LEVEL TO NO MORE THAN 76 DBA. ENCLOSURE SHALL BE WEATHER PROTECTIVE. FOR GENERATOR ON LINE 56. SPECIFY BRAND (& NUMBER IF APPLICABLE)	1	EACH		
00061	COMMODITY CODE: 285-39-120826 GENERATOR, STATIONARY, 125 KW, 1-PHASE, 60 HZ, DIESEL FUELED, WITH AUTOMATIC TRANSFER SWITCH, NO FUEL SUPPLY. CONNECTED FOR 1-PHASE, 3 WIRE 120/240 VOLTS. 12 LEAD RECONNECTABLE LEAD CONNECTION. TRANSFER SWITCH SHOULD BE RATED AT NO LESS THAN 600 AMPS CONTINUOUS, AT 1-PHASE, 3 WIRE, 120/240 VOLTS. STATIONARY GENERATOR SYSTEM SHALL INCLUDE A 5 YEAR OR 1500 HOUR PARTS AND LABOR WARRANTY TO BEGIN WHEN SYSTEM IS FIRST PLACED IN SERVICE. STATE ATS MODEL NUMBER: _____ SPECIFY BRAND (& NUMBER IF APPLICABLE)	1	EACH		
00062	COMMODITY CODE: 285-39-120826 FUEL STORAGE TANK: A SUB-BASE, DOUBLE WALL TYPE, DIESEL FUEL STORAGE TANK WITH	1	EACH		

PRICE SHEET		INVITATION TO BID			
NUMBER : 2238331 OPEN DATE : 02/25/10 TIME: 10:00 AM T-NUMBER : 92084		BIDDER:			PAGE 39
LINE NO.	COMMODITY/SERVICE DESCRIPTION	QUANTITY FROM/TO	UNIT	UNIT PRICE	EXTENDED TOTAL
	A MINIMUM OF 180 GALLONS CAPACITY. FOR GENERATOR ON LINE 61. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____				
00063	COMMODITY CODE: 285-39-120826 REMOTE ANNUNCIATOR: 12 OR 24 VOLT, NFPA 110 COMPLIANT FOR GENERATOR ON LINE 61. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____	1	EACH	_____	_____
00064	COMMODITY CODE: 285-39-120826 ENCLOSURE: WEATHER PROTECTIVE FOR GENERATOR ON LINE 61. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____	1	EACH	_____	_____
00065	COMMODITY CODE: 285-39-120826 ENCLOSURE: SOUND ATTENUATED THE ENCLOSURE SHALL REDUCE THE GENERATOR SOUND LEVEL TO NO MORE THAN 76 DBA. ENCLOSURE SHALL BE WEATHER PROTECTIVE. FOR GENERATOR ON LINE 61. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____	1	EACH	_____	_____
00066	COMMODITY CODE: 285-39-120826	1	EACH	_____	_____

PRICE SHEET		INVITATION TO BID			
NUMBER : 2238331 OPEN DATE : 02/25/10 TIME: 10:00 AM T-NUMBER : 92084		BIDDER:			PAGE 40
LINE NO.	COMMODITY/SERVICE DESCRIPTION	QUANTITY FROM/TO	UNIT	UNIT PRICE	EXTENDED TOTAL
	GENERATOR, STATIONARY, 125 KW, 3-PHASE, 60 HZ, DIESEL FUELED, WITH AUTOMATIC TRANSFER SWITCH, NO FUEL SUPPLY. CONNECTED FOR 3-PHASE, 4 WIRE 120/240 VOLTS. 12 LEAD RECONNECTABLE LEAD CONNECTION. TRANSFER SWITCH SHOULD BE RATED AT NO LESS THAN 600 AMPS CONTINUOUS, AT 3-PHASE, 4 WIRE, 120/240 VOLTS. STATIONARY GENERATOR SYSTEM SHALL INCLUDE A 5 YEAR OR 1500 HOUR PARTS AND LABOR WARRANTY TO BEGIN WHEN SYSTEM IS FIRST PLACED IN SERVICE. STATE ATS MODEL NUMBER: _____ SPECIFY BRAND (& NUMBER IF APPLICABLE) _____				
00067	COMMODITY CODE: 285-39-120826 FUEL STORAGE TANK: A SUB-BASE, DOUBLE WALL TYPE, DIESEL FUEL STORAGE TANK WITH A MINIMUM OF 180 GALLONS CAPACITY. FOR GENERATOR ON LINE 66. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____	1	EACH	_____	_____
00068	COMMODITY CODE: 285-39-120826 REMOTE ANNUNCIATOR: 12 OR 24 VOLT, NFPA 110 COMPLIANT FOR GENERATOR ON LINE 66. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____	1	EACH	_____	_____

PRICE SHEET		INVITATION TO BID			
NUMBER : 2238331 OPEN DATE : 02/25/10 TIME: 10:00 AM T-NUMBER : 92084		BIDDER:			PAGE 41
LINE NO.	COMMODITY/SERVICE DESCRIPTION	QUANTITY FROM/TO	UNIT	UNIT PRICE	EXTENDED TOTAL
00069	COMMODITY CODE: 285-39-120826 ENCLOSURE: WEATHER PROTECTIVE FOR GENERATOR ON LINE 66. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____	1	EACH	_____	_____
00070	COMMODITY CODE: 285-39-120826 ENCLOSURE: SOUND ATTENUATED THE ENCLOSURE SHALL REDUCE THE GENERATOR SOUND LEVEL TO NO MORE THAN 76 DBA. ENCLOSURE SHALL BE WEATHER PROTECTIVE. FOR GENERATOR ON LINE 66. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____	1	EACH	_____	_____
00071	COMMODITY CODE: 285-39-120826 GENERATOR, STATIONARY, 150 KW, 1-PHASE, 60 HZ, DIESEL FUELED, WITH AUTOMATIC TRANSFER SWITCH, NO FUEL SUPPLY. CONNECTED FOR 1-PHASE, 3 WIRE 120/240 VOLTS. 12 LEAD RECONNECTABLE LEAD CONNECTION. TRANSFER SWITCH SHOULD BE RATED AT NO LESS THAN 800 AMPS CONTINUOUS, AT 1-PHASE, 3 WIRE, 120/240 VOLTS. STATIONARY GENERATOR SYSTEM SHALL INCLUDE A 5 YEAR OR 1500 HOUR PARTS AND LABOR WARRANTY TO BEGIN WHEN SYSTEM IS FIRST PLACED IN SERVICE. STATE ATS MODEL NUMBER: _____ SPECIFY BRAND (& NUMBER IF APPLICABLE)	1	EACH	_____	_____

PRICE SHEET		INVITATION TO BID			
NUMBER : 2238331 OPEN DATE : 02/25/10 TIME: 10:00 AM T-NUMBER : 92084		BIDDER:			PAGE 42
LINE NO.	COMMODITY/SERVICE DESCRIPTION	QUANTITY FROM/TO	UNIT	UNIT PRICE	EXTENDED TOTAL
	APPLICABLE)				
00072	COMMODITY CODE: 285-39-120826 FUEL STORAGE TANK: A SUB-BASE, DOUBLE WALL TYPE, DIESEL FUEL STORAGE TANK WITH A MINIMUM OF 230 GALLONS CAPACITY. FOR GENERATOR ON LINE 71. SPECIFY BRAND (& NUMBER IF APPLICABLE)	1	EACH		
00073	COMMODITY CODE: 285-39-120826 REMOTE ANNUNCIATOR: 12 OR 24 VOLT, NFPA 110 COMPLIANT FOR GENERATOR ON LINE 71. SPECIFY BRAND (& NUMBER IF APPLICABLE)	1	EACH		
00074	COMMODITY CODE: 285-39-120826 ENCLOSURE: WEATHER PROTECTIVE FOR GENERATOR ON LINE 71. SPECIFY BRAND (& NUMBER IF APPLICABLE)	1	EACH		
00075	COMMODITY CODE: 285-39-120826 ENCLOSURE: SOUND ATTENUATED THE ENCLOSURE SHALL REDUCE THE GENERATOR SOUND LEVEL TO NO MORE THAN 76 DBA.	1	EACH		

PRICE SHEET		INVITATION TO BID			
NUMBER : 2238331 OPEN DATE : 02/25/10 TIME: 10:00 AM T-NUMBER : 92084		BIDDER:			PAGE 43
LINE NO.	COMMODITY/SERVICE DESCRIPTION	QUANTITY FROM/TO	UNIT	UNIT PRICE	EXTENDED TOTAL
00076	ENCLOSURE SHALL BE WEATHER PROTECTIVE. FOR GENERATOR ON LINE 71. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____ COMMODITY CODE: 285-39-120826 GENERATOR, STATIONARY, 150 KW, 3-PHASE, 60 HZ, DIESEL FUELED, WITH AUTOMATIC TRANSFER SWITCH, NO FUEL SUPPLY. CONNECTED FOR 3-PHASE, 4 WIRE 120/240 VOLTS. 12 LEAD RECONNECTABLE LEAD CONNECTION. TRANSFER SWITCH SHOULD BE RATED AT NO LESS THAN 600 AMPS CONTINUOUS, AT 3-PHASE, 4 WIRE, 120/240 VOLTS. STATIONARY GENERATOR SYSTEM SHALL INCLUDE A 5 YEAR OR 1500 HOUR PARTS AND LABOR WARRANTY TO BEGIN WHEN SYSTEM IS FIRST PLACED IN SERVICE. STATE ATS MODEL NUMBER: _____ SPECIFY BRAND (& NUMBER IF APPLICABLE) _____	1	EACH	_____	_____
00077	COMMODITY CODE: 285-39-120826 FUEL STORAGE TANK: A SUB-BASE, DOUBLE WALL TYPE, DIESEL FUEL STORAGE TANK WITH A MINIMUM OF 230 GALLONS CAPACITY. FOR GENERATOR ON LINE 76. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____	1	EACH	_____	_____
00078	COMMODITY CODE: 285-39-120826	1	EACH	_____	_____

PRICE SHEET		INVITATION TO BID			
NUMBER : 2238331 OPEN DATE : 02/25/10 TIME: 10:00 AM T-NUMBER : 92084		BIDDER:			PAGE 44
LINE NO.	COMMODITY/SERVICE DESCRIPTION	QUANTITY FROM/TO	UNIT	UNIT PRICE	EXTENDED TOTAL
	REMOTE ANNUNCIATOR: 12 OR 24 VOLT, NFPA 110 COMPLIANT FOR GENERATOR ON LINE 76. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____				
00079	COMMODITY CODE: 285-39-120826 ENCLOSURE: WEATHER PROTECTIVE FOR GENERATOR ON LINE 76. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____	1	EACH	_____	_____
00080	COMMODITY CODE: 285-39-120826 ENCLOSURE: SOUND ATTENUATED THE ENCLOSURE SHALL REDUCE THE GENERATOR SOUND LEVEL TO NO MORE THAN 76 DBA. ENCLOSURE SHALL BE WEATHER PROTECTIVE. FOR GENERATOR ON LINE 76. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____	1	EACH	_____	_____
00081	COMMODITY CODE: 285-39-120826 GENERATOR, STATIONARY, 200 KW, 1-PHASE, 60 HZ, DIESEL FUELED, WITH AUTOMATIC TRANSFER SWITCH, NO FUEL SUPPLY. CONNECTED FOR 1-PHASE, 3 WIRE 120/240 VOLTS. 12 LEAD RECONNECTABLE LEAD CONNECTION. TRANSFER SWITCH SHOULD BE RATED AT NO LESS THAN 600 AMPS CONTINUOUS, AT 1-PHASE, 3 WIRE, 120/240 VOLTS.	1	EACH	_____	_____

PRICE SHEET		INVITATION TO BID			
NUMBER : 2238331 OPEN DATE : 02/25/10 TIME: 10:00 AM T-NUMBER : 92084		BIDDER:			PAGE 45
LINE NO.	COMMODITY/SERVICE DESCRIPTION	QUANTITY FROM/TO	UNIT	UNIT PRICE	EXTENDED TOTAL
00082	STATIONARY GENERATOR SYSTEM SHALL INCLUDE A 5 YEAR OR 1500 HOUR PARTS AND LABOR WARRANTY TO BEGIN WHEN SYSTEM IS FIRST PLACED IN SERVICE. STATE ATS MODEL NUMBER: _____ SPECIFY BRAND (& NUMBER IF APPLICABLE) _____ COMMODITY CODE: 285-39-120826 FUEL STORAGE TANK: A SUB-BASE, DOUBLE WALL TYPE, DIESEL FUEL STORAGE TANK WITH A MINIMUM OF 300 GALLONS CAPACITY. FOR GENERATOR ON LINE 81. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____	1	EACH	_____	_____
00083	COMMODITY CODE: 285-39-120826 REMOTE ANNUNCIATOR: 12 OR 24 VOLT, NFPA 110 COMPLIANT FOR GENERATOR ON LINE 81. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____	1	EACH	_____	_____
00084	COMMODITY CODE: 285-39-120826 ENCLOSURE: WEATHER PROTECTIVE FOR GENERATOR ON LINE 81. SPECIFY BRAND (& NUMBER IF APPLICABLE)	1	EACH	_____	_____

PRICE SHEET		INVITATION TO BID			
NUMBER : 2238331 OPEN DATE : 02/25/10 TIME: 10:00 AM T-NUMBER : 92084		BIDDER:			PAGE 46
LINE NO.	COMMODITY/SERVICE DESCRIPTION	QUANTITY FROM/TO	UNIT	UNIT PRICE	EXTENDED TOTAL
00085	COMMODITY CODE: 285-39-120826 ENCLOSURE: SOUND ATTENUATED THE ENCLOSURE SHALL REDUCE THE GENERATOR SOUND LEVEL TO NO MORE THAN 76 DBA. ENCLOSURE SHALL BE WEATHER PROTECTIVE. FOR GENERATOR ON LINE 81. SPECIFY BRAND (& NUMBER IF APPLICABLE)	1	EACH		
00086	COMMODITY CODE: 285-39-120826 GENERATOR, STATIONARY, 200 KW, 3-PHASE, 60 HZ, DIESEL FUELED, WITH AUTOMATIC TRANSFER SWITCH, NO FUEL SUPPLY. CONNECTED FOR 3-PHASE, 4 WIRE 120/240 VOLTS. 12 LEAD RECONNECTABLE LEAD CONNECTION. TRANSFER SWITCH SHOULD BE RATED AT NO LESS THAN 600 AMPS CONTINUOUS, AT 3-PHASE, 4 WIRE, 120/240 VOLTS. STATIONARY GENERATOR SYSTEM SHALL INCLUDE A 5 YEAR OR 1500 HOUR PARTS AND LABOR WARRANTY TO BEGIN WHEN SYSTEM IS FIRST PLACED IN SERVICE. STATE ATS MODEL NUMBER: _____ SPECIFY BRAND (& NUMBER IF APPLICABLE)	1	EACH		
00087	COMMODITY CODE: 285-39-120826 FUEL STORAGE TANK: A SUB-BASE, DOUBLE WALL TYPE, DIESEL FUEL STORAGE TANK WITH	1	EACH		

PRICE SHEET		INVITATION TO BID			
NUMBER : 2238331 OPEN DATE : 02/25/10 TIME: 10:00 AM T-NUMBER : 92084		BIDDER:			PAGE 47
LINE NO.	COMMODITY/SERVICE DESCRIPTION	QUANTITY FROM/TO	UNIT	UNIT PRICE	EXTENDED TOTAL
	A MINIMUM OF 300 GALLONS CAPACITY. FOR GENERATOR ON LINE 86. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____				
00088	COMMODITY CODE: 285-39-120826 REMOTE ANNUNCIATOR: 12 OR 24 VOLT, NFPA 110 COMPLIANT FOR GENERATOR ON LINE 86. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____	1	EACH	_____	_____
00089	COMMODITY CODE: 285-39-120826 ENCLOSURE: WEATHER PROTECTIVE FOR GENERATOR ON LINE 86. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____	1	EACH	_____	_____
00090	COMMODITY CODE: 285-39-120826 ENCLOSURE: SOUND ATTENUATED THE ENCLOSURE SHALL REDUCE THE GENERATOR SOUND LEVEL TO NO MORE THAN 76 DBA. ENCLOSURE SHALL BE WEATHER PROTECTIVE. FOR GENERATOR ON LINE 86. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____	1	EACH	_____	_____
00091	COMMODITY CODE: 285-39-120826	1	EACH	_____	_____

PRICE SHEET		INVITATION TO BID			
NUMBER : 2238331 OPEN DATE : 02/25/10 TIME: 10:00 AM T-NUMBER : 92084		BIDDER:			PAGE 48
LINE NO.	COMMODITY/SERVICE DESCRIPTION	QUANTITY FROM/TO	UNIT	UNIT PRICE	EXTENDED TOTAL
	GENERATOR, STATIONARY, 500 KW, 3-PHASE, 60 HZ, DIESEL FUELED, WITH AUTOMATIC TRANSFER SWITCH, NO FUEL SUPPLY. CONNECTED FOR 3-PHASE, 4 WIRE 277/480 VOLTS. 12 LEAD RECONNECTABLE LEAD CONNECTION. TRANSFER SWITCH SHOULD BE RATED AT NO LESS THAN 1000 AMPS CONTINUOUS, AT 3-PHASE, 4 WIRE, 277/480 VOLTS. STATIONARY GENERATOR SYSTEM SHALL INCLUDE A 5 YEAR OR 1500 HOUR PARTS AND LABOR WARRANTY TO BEGIN WHEN SYSTEM IS FIRST PLACED IN SERVICE. STATE ATS MODEL NUMBER: _____ SPECIFY BRAND (& NUMBER IF APPLICABLE) _____				
00092	COMMODITY CODE: 285-39-120826 FUEL STORAGE TANK: A SUB-BASE, DOUBLE WALL TYPE, DIESEL FUEL STORAGE TANK WITH A MINIMUM OF 400 GALLONS CAPACITY. FOR GENERATOR ON LINE 91. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____	1	EACH	_____	_____
00093	COMMODITY CODE: 285-39-120826 REMOTE ANNUNCIATOR: 12 OR 24 VOLT, NFPA 110 COMPLIANT FOR GENERATOR ON LINE 91. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____	1	EACH	_____	_____

PRICE SHEET		INVITATION TO BID			
NUMBER : 2238331 OPEN DATE : 02/25/10 TIME: 10:00 AM T-NUMBER : 92084		BIDDER:			PAGE 49
LINE NO.	COMMODITY/SERVICE DESCRIPTION	QUANTITY FROM/TO	UNIT	UNIT PRICE	EXTENDED TOTAL
00094	COMMODITY CODE: 285-39-120826 ENCLOSURE: WEATHER PROTECTIVE FOR GENERATOR ON LINE 91. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____	1	EACH	_____	_____
00095	COMMODITY CODE: 285-39-120826 ENCLOSURE: SOUND ATTENUATED THE ENCLOSURE SHALL REDUCE THE GENERATOR SOUND LEVEL TO NO MORE THAN 76 DBA. ENCLOSURE SHALL BE WEATHER PROTECTIVE. FOR GENERATOR ON LINE 91. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____	1	EACH	_____	_____
00096	COMMODITY CODE: 285-39-120826 GENERATOR, STATIONARY, 20 KW, 1-PHASE, 60 HZ, NATURAL GAS FUELED, WITH AUTOMATIC TRANSFER SWITCH. CONNECTED FOR 1-PHASE, 3 WIRE 120/240 VOLTS. 12 LEAD RECONNECTABLE LEAD CONNECTION. TRANSFER SWITCH SHOULD BE RATED AT NO LESS THAN 200 AMPS CONTINUOUS, AT 1-PHASE, 3 WIRE, 120/240 VOLTS. STATIONARY GENERATOR SYSTEM SHALL INCLUDE A 5 YEAR OR 1500 HOUR PARTS AND LABOR WARRANTY TO BEGIN WHEN SYSTEM IS FIRST PLACED IN SERVICE. STATE ATS MODEL NUMBER: _____ SPECIFY BRAND (& NUMBER IF APPLICABLE)	1	EACH	_____	_____

PRICE SHEET		INVITATION TO BID			
NUMBER : 2238331 OPEN DATE : 02/25/10 TIME: 10:00 AM T-NUMBER : 92084		BIDDER:			PAGE 50
LINE NO.	COMMODITY/SERVICE DESCRIPTION	QUANTITY FROM/TO	UNIT	UNIT PRICE	EXTENDED TOTAL
	APPLICABLE)				
00097	COMMODITY CODE: 285-39-120826 REMOTE ANNUNCIATOR: 12 OR 24 VOLT, NFPA 110 COMPLIANT FOR GENERATOR ON LINE 96. SPECIFY BRAND (& NUMBER IF APPLICABLE)	1	EACH		
00098	COMMODITY CODE: 285-39-120826 ENCLOSURE: WEATHER PROTECTIVE FOR GENERATOR ON LINE 96. SPECIFY BRAND (& NUMBER IF APPLICABLE)	1	EACH		
00099	COMMODITY CODE: 285-39-120826 ENCLOSURE: SOUND ATTENUATED THE ENCLOSURE SHALL REDUCE THE GENERATOR SOUND LEVEL TO NO MORE THAN 76 DBA. ENCLOSURE SHALL BE WEATHER PROTECTIVE. FOR GENERATOR ON LINE 96. SPECIFY BRAND (& NUMBER IF APPLICABLE)	1	EACH		
00100	COMMODITY CODE: 285-39-120826 GENERATOR, STATIONARY, 20 KW, 3-PHASE, 60 HZ, NATURAL GAS FUELED, WITH	1	EACH		

PRICE SHEET		INVITATION TO BID			
NUMBER : 2238331 OPEN DATE : 02/25/10 TIME: 10:00 AM T-NUMBER : 92084		BIDDER:			PAGE 51
LINE NO.	COMMODITY/SERVICE DESCRIPTION	QUANTITY FROM/TO	UNIT	UNIT PRICE	EXTENDED TOTAL
	AUTOMATIC TRANSFER SWITCH. CONNECTED FOR 3-PHASE, 4 WIRE 120/240 VOLTS. 12 LEAD RECONNECTABLE LEAD CONNECTION. TRANSFER SWITCH SHOULD BE RATED AT NO LESS THAN 200 AMPS CONTINUOUS, AT 3-PHASE, 4 WIRE, 120/240 VOLTS. STATIONARY GENERATOR SYSTEM SHALL INCLUDE A 5 YEAR OR 1500 HOUR PARTS AND LABOR WARRANTY TO BEGIN WHEN SYSTEM IS FIRST PLACED IN SERVICE. STATE ATS MODEL NUMBER: _____ SPECIFY BRAND (& NUMBER IF APPLICABLE) _____				
00101	COMMODITY CODE: 285-39-120826 REMOTE ANNUNCIATOR: 12 OR 24 VOLT, NFPA 110 COMPLIANT FOR GENERATOR ON LINE 100. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____	1	EACH	_____	_____
00102	COMMODITY CODE: 285-39-120826 ENCLOSURE: WEATHER PROTECTIVE FOR GENERATOR ON LINE 100. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____	1	EACH	_____	_____
00103	COMMODITY CODE: 285-39-120826	1	EACH	_____	_____

PRICE SHEET		INVITATION TO BID			
NUMBER : 2238331 OPEN DATE : 02/25/10 TIME: 10:00 AM T-NUMBER : 92084		BIDDER:			PAGE 52
LINE NO.	COMMODITY/SERVICE DESCRIPTION	QUANTITY FROM/TO	UNIT	UNIT PRICE	EXTENDED TOTAL
	ENCLOSURE: SOUND ATTENUATED THE ENCLOSURE SHALL REDUCE THE GENERATOR SOUND LEVEL TO NO MORE THAN 76 DBA. ENCLOSURE SHALL BE WEATHER PROTECTIVE. FOR GENERATOR ON LINE 100. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____				
00104	COMMODITY CODE: 285-39-120826 GENERATOR, STATIONARY, 50 KW, 1-PHASE, 60 HZ, NATURAL GAS FUELED, WITH AUTOMATIC TRANSFER SWITCH. CONNECTED FOR 1-PHASE, 3 WIRE 120/240 VOLTS. 12 LEAD RECONNECTABLE LEAD CONNECTION. TRANSFER SWITCH SHOULD BE RATED AT NO LESS THAN 300 AMPS CONTINUOUS, AT 1-PHASE, 3 WIRE, 120/240 VOLTS. STATIONARY GENERATOR SYSTEM SHALL INCLUDE A 5 YEAR OR 1500 HOUR PARTS AND LABOR WARRANTY TO BEGIN WHEN SYSTEM IS FIRST PLACED IN SERVICE. STATE ATS MODEL NUMBER: _____ SPECIFY BRAND (& NUMBER IF APPLICABLE) _____	1	EACH	_____	_____
00105	COMMODITY CODE: 285-39-120826 REMOTE ANNUNCIATOR: 12 OR 24 VOLT, NFPA 110 COMPLIANT FOR GENERATOR ON LINE 104. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____	1	EACH	_____	_____

PRICE SHEET		INVITATION TO BID			
NUMBER : 2238331 OPEN DATE : 02/25/10 TIME: 10:00 AM T-NUMBER : 92084		BIDDER:			PAGE 53
LINE NO.	COMMODITY/SERVICE DESCRIPTION	QUANTITY FROM/TO	UNIT	UNIT PRICE	EXTENDED TOTAL
00106	COMMODITY CODE: 285-39-120826 ENCLOSURE: WEATHER PROTECTIVE FOR GENERATOR ON LINE 104. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____	1	EACH	_____	_____
00107	COMMODITY CODE: 285-39-120826 ENCLOSURE: SOUND ATTENUATED THE ENCLOSURE SHALL REDUCE THE GENERATOR SOUND LEVEL TO NO MORE THAN 76 DBA. ENCLOSURE SHALL BE WEATHER PROTECTIVE. FOR GENERATOR ON LINE 104. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____	1	EACH	_____	_____
00108	COMMODITY CODE: 285-39-120826 GENERATOR, STATIONARY, 50 KW, 3-PHASE, 60 HZ, NATURAL GAS FUELED, WITH AUTOMATIC TRANSFER SWITCH. CONNECTED FOR 3-PHASE, 4 WIRE 120/240 VOLTS. 12 LEAD RECONNECTABLE LEAD CONNECTION. TRANSFER SWITCH SHOULD BE RATED AT NO LESS THAN 300 AMPS CONTINUOUS, AT 3-PHASE, 4 WIRE, 120/240 VOLTS. STATIONARY GENERATOR SYSTEM SHALL INCLUDE A 5 YEAR OR 1500 HOUR PARTS AND LABOR WARRANTY TO BEGIN WHEN SYSTEM IS FIRST PLACED IN SERVICE. STATE ATS MODEL NUMBER: _____ SPECIFY BRAND (& NUMBER IF APPLICABLE)	1	EACH	_____	_____

PRICE SHEET		INVITATION TO BID			
NUMBER : 2238331 OPEN DATE : 02/25/10 TIME: 10:00 AM T-NUMBER : 92084		BIDDER:			PAGE 54
LINE NO.	COMMODITY/SERVICE DESCRIPTION	QUANTITY FROM/TO	UNIT	UNIT PRICE	EXTENDED TOTAL
	APPLICABLE)				
00109	COMMODITY CODE: 285-39-120826 REMOTE ANNUNCIATOR: 12 OR 24 VOLT, NFPA 110 COMPLIANT FOR GENERATOR ON LINE 108. SPECIFY BRAND (& NUMBER IF APPLICABLE)	1	EACH		
00110	COMMODITY CODE: 285-39-120826 ENCLOSURE: WEATHER PROTECTIVE FOR GENERATOR ON LINE 108. SPECIFY BRAND (& NUMBER IF APPLICABLE)	1	EACH		
00111	COMMODITY CODE: 285-39-120826 ENCLOSURE: SOUND ATTENUATED THE ENCLOSURE SHALL REDUCE THE GENERATOR SOUND LEVEL TO NO MORE THAN 76 DBA. ENCLOSURE SHALL BE WEATHER PROTECTIVE. FOR GENERATOR ON LINE 108. SPECIFY BRAND (& NUMBER IF APPLICABLE)	1	EACH		
00112	COMMODITY CODE: 285-39-120826 GENERATOR, STATIONARY, 100 KW, 1-PHASE, 60 HZ, NATURAL GAS FUELED, WITH	1	EACH		

PRICE SHEET		INVITATION TO BID			
NUMBER : 2238331 OPEN DATE : 02/25/10 TIME: 10:00 AM T-NUMBER : 92084		BIDDER:			PAGE 55
LINE NO.	COMMODITY/SERVICE DESCRIPTION	QUANTITY FROM/TO	UNIT	UNIT PRICE	EXTENDED TOTAL
	AUTOMATIC TRANSFER SWITCH. CONNECTED FOR 1-PHASE, 3 WIRE 120/240 VOLTS. 12 LEAD RECONNECTABLE LEAD CONNECTION. TRANSFER SWITCH SHOULD BE RATED AT NO LESS THAN 600 AMPS CONTINUOUS, AT 1-PHASE, 3 WIRE, 120/240 VOLTS. STATIONARY GENERATOR SYSTEM SHALL INCLUDE A 5 YEAR OR 1500 HOUR PARTS AND LABOR WARRANTY TO BEGIN WHEN SYSTEM IS FIRST PLACED IN SERVICE. STATE ATS MODEL NUMBER: _____ SPECIFY BRAND (& NUMBER IF APPLICABLE) _____				
00113	COMMODITY CODE: 285-39-120826 REMOTE ANNUNCIATOR: 12 OR 24 VOLT, NFPA 110 COMPLIANT FOR GENERATOR ON LINE 112. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____	1	EACH	_____	_____
00114	COMMODITY CODE: 285-39-120826 ENCLOSURE: WEATHER PROTECTIVE FOR GENERATOR ON LINE 112. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____	1	EACH	_____	_____
00115	COMMODITY CODE: 285-39-120826	1	EACH	_____	_____

PRICE SHEET		INVITATION TO BID			
NUMBER : 2238331 OPEN DATE : 02/25/10 TIME: 10:00 AM T-NUMBER : 92084		BIDDER:			PAGE 56
LINE NO.	COMMODITY/SERVICE DESCRIPTION	QUANTITY FROM/TO	UNIT	UNIT PRICE	EXTENDED TOTAL
	ENCLOSURE: SOUND ATTENUATED THE ENCLOSURE SHALL REDUCE THE GENERATOR SOUND LEVEL TO NO MORE THAN 76 DBA. ENCLOSURE SHALL BE WEATHER PROTECTIVE. FOR GENERATOR ON LINE 112. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____				
00116	COMMODITY CODE: 285-39-120826 GENERATOR, STATIONARY, 100 KW, 3-PHASE, 60 HZ, NATURAL GAS FUELED, WITH AUTOMATIC TRANSFER SWITCH. CONNECTED FOR 3-PHASE, 4 WIRE 120/240 VOLTS. 12 LEAD RECONNECTABLE LEAD CONNECTION. TRANSFER SWITCH SHOULD BE RATED AT NO LESS THAN 400 AMPS CONTINUOUS, AT 3-PHASE, 4 WIRE, 120/240 VOLTS. STATIONARY GENERATOR SYSTEM SHALL INCLUDE A 5 YEAR OR 1500 HOUR PARTS AND LABOR WARRANTY TO BEGIN WHEN SYSTEM IS FIRST PLACED IN SERVICE. STATE ATS MODEL NUMBER: _____ SPECIFY BRAND (& NUMBER IF APPLICABLE) _____	1	EACH	_____	_____
00117	COMMODITY CODE: 285-39-120826 REMOTE ANNUNCIATOR: 12 OR 24 VOLT, NFPA 110 COMPLIANT FOR GENERATOR ON LINE 116. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____	1	EACH	_____	_____

PRICE SHEET		INVITATION TO BID			
NUMBER : 2238331 OPEN DATE : 02/25/10 TIME: 10:00 AM T-NUMBER : 92084		BIDDER:			PAGE 57
LINE NO.	COMMODITY/SERVICE DESCRIPTION	QUANTITY FROM/TO	UNIT	UNIT PRICE	EXTENDED TOTAL
00118	COMMODITY CODE: 285-39-120826 ENCLOSURE: WEATHER PROTECTIVE FOR GENERATOR ON LINE 116. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____	1	EACH	_____	_____
00119	COMMODITY CODE: 285-39-120826 ENCLOSURE: SOUND ATTENUATED THE ENCLOSURE SHALL REDUCE THE GENERATOR SOUND LEVEL TO NO MORE THAN 76 DBA. ENCLOSURE SHALL BE WEATHER PROTECTIVE. FOR GENERATOR ON LINE 116. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____	1	EACH	_____	_____
00120	COMMODITY CODE: 285-39-120826 GENERATOR, STATIONARY, 150 KW, 1-PHASE, 60 HZ, NATURAL GAS FUELED, WITH AUTOMATIC TRANSFER SWITCH. CONNECTED FOR 1-PHASE, 3 WIRE 120/240 VOLTS. 12 LEAD RECONNECTABLE LEAD CONNECTION. TRANSFER SWITCH SHOULD BE RATED AT NO LESS THAN 800 AMPS CONTINUOUS, AT 1-PHASE, 3 WIRE, 120/240 VOLTS. STATIONARY GENERATOR SYSTEM SHALL INCLUDE A 5 YEAR OR 1500 HOUR PARTS AND LABOR WARRANTY TO BEGIN WHEN SYSTEM IS FIRST PLACED IN SERVICE. STATE ATS MODEL NUMBER: _____ SPECIFY BRAND (& NUMBER IF APPLICABLE)	1	EACH	_____	_____

PRICE SHEET		INVITATION TO BID			
NUMBER : 2238331 OPEN DATE : 02/25/10 TIME: 10:00 AM T-NUMBER : 92084		BIDDER:			PAGE 58
LINE NO.	COMMODITY/SERVICE DESCRIPTION	QUANTITY FROM/TO	UNIT	UNIT PRICE	EXTENDED TOTAL
	APPLICABLE)				
00121	COMMODITY CODE: 285-39-120826 REMOTE ANNUNCIATOR: 12 OR 24 VOLT, NFPA 110 COMPLIANT FOR GENERATOR ON LINE 120. SPECIFY BRAND (& NUMBER IF APPLICABLE)	1	EACH		
00122	COMMODITY CODE: 285-39-120826 ENCLOSURE: WEATHER PROTECTIVE FOR GENERATOR ON LINE 120. SPECIFY BRAND (& NUMBER IF APPLICABLE)	1	EACH		
00123	COMMODITY CODE: 285-39-120826 ENCLOSURE: SOUND ATTENUATED THE ENCLOSURE SHALL REDUCE THE GENERATOR SOUND LEVEL TO NO MORE THAN 76 DBA. ENCLOSURE SHALL BE WEATHER PROTECTIVE. FOR GENERATOR ON LINE 120. SPECIFY BRAND (& NUMBER IF APPLICABLE)	1	EACH		
00124	COMMODITY CODE: 285-39-120826 GENERATOR, STATIONARY, 150 KW, 3-PHASE, 60 HZ, NATURAL GAS FUELED, WITH	1	EACH		

PRICE SHEET		INVITATION TO BID			
NUMBER : 2238331 OPEN DATE : 02/25/10 TIME: 10:00 AM T-NUMBER : 92084		BIDDER:			PAGE 59
LINE NO.	COMMODITY/SERVICE DESCRIPTION	QUANTITY FROM/TO	UNIT	UNIT PRICE	EXTENDED TOTAL
	AUTOMATIC TRANSFER SWITCH. CONNECTED FOR 3-PHASE, 4 WIRE 120/240 VOLTS. 12 LEAD RECONNECTABLE LEAD CONNECTION. TRANSFER SWITCH SHOULD BE RATED AT NO LESS THAN 600 AMPS CONTINUOUS, AT 3-PHASE, 4 WIRE, 120/240 VOLTS. STATIONARY GENERATOR SYSTEM SHALL INCLUDE A 5 YEAR OR 1500 HOUR PARTS AND LABOR WARRANTY TO BEGIN WHEN SYSTEM IS FIRST PLACED IN SERVICE. STATE ATS MODEL NUMBER: _____ SPECIFY BRAND (& NUMBER IF APPLICABLE) _____				
00125	COMMODITY CODE: 285-39-120826 REMOTE ANNUNCIATOR: 12 OR 24 VOLT, NFPA 110 COMPLIANT FOR GENERATOR ON LINE 124. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____	1	EACH	_____	_____
00126	COMMODITY CODE: 285-39-120826 ENCLOSURE: WEATHER PROTECTIVE FOR GENERATOR ON LINE 124. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____	1	EACH	_____	_____
00127	COMMODITY CODE: 285-39-120826	1	EACH	_____	_____

PRICE SHEET		INVITATION TO BID			
NUMBER : 2238331 OPEN DATE : 02/25/10 TIME: 10:00 AM T-NUMBER : 92084		BIDDER:			PAGE 60
LINE NO.	COMMODITY/SERVICE DESCRIPTION	QUANTITY FROM/TO	UNIT	UNIT PRICE	EXTENDED TOTAL
	ENCLOSURE: SOUND ATTENUATED THE ENCLOSURE SHALL REDUCE THE GENERATOR SOUND LEVEL TO NO MORE THAN 76 DBA. ENCLOSURE SHALL BE WEATHER PROTECTIVE. FOR GENERATOR ON LINE 124. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____				
00128	COMMODITY CODE: 285-39-120826 GENERATOR, STATIONARY, 200 KW, 1-PHASE, 60 HZ, NATURAL GAS FUELED, WITH AUTOMATIC TRANSFER SWITCH. CONNECTED FOR 1-PHASE, 3 WIRE 120/240 VOLTS. 12 LEAD RECONNECTABLE LEAD CONNECTION. TRANSFER SWITCH SHOULD BE RATED AT NO LESS THAN 600 AMPS CONTINUOUS, AT 1-PHASE, 3 WIRE, 120/240 VOLTS. STATIONARY GENERATOR SYSTEM SHALL INCLUDE A 5 YEAR OR 1500 HOUR PARTS AND LABOR WARRANTY TO BEGIN WHEN SYSTEM IS FIRST PLACED IN SERVICE. STATE ATS MODEL NUMBER: _____ SPECIFY BRAND (& NUMBER IF APPLICABLE) _____	1	EACH	_____	_____
00129	COMMODITY CODE: 285-39-120826 REMOTE ANNUNCIATOR: 12 OR 24 VOLT, NFPA 110 COMPLIANT FOR GENERATOR ON LINE 128. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____	1	EACH	_____	_____

PRICE SHEET		INVITATION TO BID			
NUMBER : 2238331 OPEN DATE : 02/25/10 TIME: 10:00 AM T-NUMBER : 92084		BIDDER:			PAGE 61
LINE NO.	COMMODITY/SERVICE DESCRIPTION	QUANTITY FROM/TO	UNIT	UNIT PRICE	EXTENDED TOTAL
00130	COMMODITY CODE: 285-39-120826 ENCLOSURE: WEATHER PROTECTIVE FOR GENERATOR ON LINE 128. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____	1	EACH	_____	_____
00131	COMMODITY CODE: 285-39-120826 ENCLOSURE: SOUND ATTENUATED THE ENCLOSURE SHALL REDUCE THE GENERATOR SOUND LEVEL TO NO MORE THAN 76 DBA. ENCLOSURE SHALL BE WEATHER PROTECTIVE. FOR GENERATOR ON LINE 128. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____	1	EACH	_____	_____
00132	COMMODITY CODE: 285-39-120414 GENERATOR, STATIONARY, 200 KW, 3-PHASE, 60 HZ, NATURAL GAS FUELED, WITH AUTOMATIC TRANSFER SWITCH. CONNECTED FOR 3-PHASE, 4 WIRE 120/240 VOLTS. 12 LEAD RECONNECTABLE LEAD CONNECTION. TRANSFER SWITCH SHOULD BE RATED AT NO LESS THAN 600 AMPS CONTINUOUS, AT 3-PHASE, 4 WIRE, 120/240 VOLTS. STATIONARY GENERATOR SYSTEM SHALL INCLUDE A 5 YEAR OR 1500 HOUR PARTS AND LABOR WARRANTY TO BEGIN WHEN SYSTEM IS FIRST PLACED IN SERVICE. STATE ATS MODEL NUMBER: _____ SPECIFY BRAND (& NUMBER IF APPLICABLE)	1	EACH	_____	_____

PRICE SHEET		INVITATION TO BID			
NUMBER : 2238331 OPEN DATE : 02/25/10 TIME: 10:00 AM T-NUMBER : 92084		BIDDER:			PAGE 62
LINE NO.	COMMODITY/SERVICE DESCRIPTION	QUANTITY FROM/TO	UNIT	UNIT PRICE	EXTENDED TOTAL
	APPLICABLE)				
00133	COMMODITY CODE: 285-39-120826 REMOTE ANNUNCIATOR: 12 OR 24 VOLT, NFPA 110 COMPLIANT FOR GENERATOR ON LINE 132. SPECIFY BRAND (& NUMBER IF APPLICABLE)	1	EACH		
00134	COMMODITY CODE: 285-39-120826 ENCLOSURE: WEATHER PROTECTIVE FOR GENERATOR ON LINE 132. SPECIFY BRAND (& NUMBER IF APPLICABLE)	1	EACH		
00135	COMMODITY CODE: 285-39-120826 ENCLOSURE: SOUND ATTENUATED THE ENCLOSURE SHALL REDUCE THE GENERATOR SOUND LEVEL TO NO MORE THAN 76 DBA. ENCLOSURE SHALL BE WEATHER PROTECTIVE. FOR GENERATOR ON LINE 132. SPECIFY BRAND (& NUMBER IF APPLICABLE)	1	EACH		
00136	COMMODITY CODE: 285-39-120826 GENERATOR, TOWABLE, 20 KW, 60 HZ, DIESEL FUELED. SHALL HAVE ADJUSTABLE	1	EACH		

PRICE SHEET		INVITATION TO BID			
NUMBER : 2238331 OPEN DATE : 02/25/10 TIME: 10:00 AM T-NUMBER : 92084		BIDDER:			PAGE 63
LINE NO.	COMMODITY/SERVICE DESCRIPTION	QUANTITY FROM/TO	UNIT	UNIT PRICE	EXTENDED TOTAL
	VOLTAGE TO INCLUDE AT LEAST 1-PHASE 120/240 AND 3-PHASE 240/480 VOLTS. SHALL INCLUDE A SOUND ATTENUATED ENCLOSURE. SHOULD BE MOUNTED ON A TANDUM AXLE TRAILER. SHALL INCLUDE A TRAILER BREAKING SYSTEM. SHALL BE DOT APPROVED FOR HIGHWAY USE. SHOULD INCLUDE A 12/24 VOLT DC SYSTEM. SHALL INCLUDE A FUEL TANK CAPABLE OF SUPPORTING CONTINUOUS OPERATION AT 100% LOAD FOR AT LEAST 8 HOURS. TOWABLE GENERATOR SYSTEM SHALL INCLUDE A MINIMUM WARRANTY OF 1 YEAR OR 3000 HOURS. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____				
00137	COMMODITY CODE: 285-39-120826 GENERATOR, TOWABLE, 50 KW, 60 HZ, DIESEL FUELED. SHALL HAVE ADJUSTABLE VOLTAGE TO INCLUDE AT LEAST 1-PHASE 120/240 AND 3-PHASE 240/480 VOLTS. SHALL INCLUDE A SOUND ATTENUATED ENCLOSURE. SHOULD BE MOUNTED ON A TANDUM AXLE TRAILER. SHALL INCLUDE A TRAILER BREAKING SYSTEM. SHALL BE DOT APPROVED FOR HIGHWAY USE. SHOULD INCLUDE A 12/24 VOLT DC SYSTEM. SHALL INCLUDE A FUEL TANK CAPABLE OF SUPPORTING CONTINUOUS OPERATION AT 100% LOAD FOR AT LEAST 8 HOURS. TOWABLE GENERATOR SYSTEM SHALL INCLUDE A MINIMUM WARRANTY OF 1 YEAR OR 3000 HOURS. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____	1	EACH		
00138	COMMODITY CODE: 285-39-120826	1	EACH		

PRICE SHEET		INVITATION TO BID			
NUMBER : 2238331 OPEN DATE : 02/25/10 TIME: 10:00 AM T-NUMBER : 92084		BIDDER:			PAGE 64
LINE NO.	COMMODITY/SERVICE DESCRIPTION	QUANTITY FROM/TO	UNIT	UNIT PRICE	EXTENDED TOTAL
	GENERATOR, TOWABLE, 100 KW, 60 HZ, DIESEL FUELED. SHALL HAVE ADJUSTABLE VOLTAGE TO INCLUDE AT LEAST 1-PHASE 120/240 AND 3-PHASE 240/480 VOLTS. SHALL INCLUDE A SOUND ATTENUATED ENCLOSURE. SHALL BE MOUNTED ON A TANDUM AXLE TRAILER. SHALL INCLUDE A TRAILER BREAKING SYSTEM. SHALL BE DOT APPROVED FOR HIGHWAY USE. SHOULD INCLUDE A 12/24 VOLT DC SYSTEM. SHALL INCLUDE A FUEL TANK CAPABLE OF SUPPORTING CONTINUOUS OPERATION AT 100% LOAD FOR AT LEAST 8 HOURS. TOWABLE GENERATOR SYSTEM SHALL INCLUDE A MINIMUM WARRANTY OF 1 YEAR OR 3000 HOURS. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____				
00139	COMMODITY CODE: 285-39-120826 GENERATOR, TOWABLE, 150 KW, 60 HZ, DIESEL FUELED. SHALL HAVE ADJUSTABLE VOLTAGE TO INCLUDE AT LEAST 1-PHASE 120/240 AND 3-PHASE 240/480 VOLTS. SHALL INCLUDE A SOUND ATTENUATED ENCLOSURE. SHALL BE MOUNTED ON A TANDUM AXLE TRAILER. SHALL INCLUDE A TRAILER BREAKING SYSTEM. SHALL BE DOT APPROVED FOR HIGHWAY USE. SHOULD INCLUDE A 12/24 VOLT DC SYSTEM. SHALL INCLUDE A FUEL TANK CAPABLE OF SUPPORTING CONTINUOUS OPERATION AT 100% LOAD FOR AT LEAST 8 HOURS. TOWABLE GENERATOR SYSTEM SHALL INCLUDE A MINIMUM WARRANTY OF 1 YEAR OR 3000 HOURS. SPECIFY BRAND (& NUMBER IF APPLICABLE) _____	1	EACH	_____	_____
00140	COMMODITY CODE: 285-39-120826	1	EACH	_____	_____

PRICE SHEET		INVITATION TO BID			
NUMBER : 2238331 OPEN DATE : 02/25/10 TIME: 10:00 AM T-NUMBER : 92084		BIDDER:			PAGE 65
LINE NO.	COMMODITY/SERVICE DESCRIPTION	QUANTITY FROM/TO	UNIT	UNIT PRICE	EXTENDED TOTAL
00141	<p>GENERATOR, TOWABLE, 200 KW, 60 HZ, DIESEL FUELED. SHALL HAVE ADJUSTABLE VOLTAGE TO INCLUDE AT LEAST 1-PHASE 120/240 AND 3-PHASE 240/480 VOLTS. SHALL INCLUDE A SOUND ATTENUATED ENCLOSURE. SHALL BE MOUNTED ON A TANDUM AXLE TRAILER. SHALL INCLUDE A TRAILER BREAKING SYSTEM. SHALL BE DOT APPROVED FOR HIGHWAY USE. SHOULD INCLUDE A 12/24 VOLT DC SYSTEM. SHALL INCLUDE A FUEL TANK CAPABLE OF SUPPORTING CONTINUOUS OPERATION AT 100% LOAD FOR AT LEAST 8 HOURS.</p> <p>TOWABLE GENERATOR SYSTEM SHALL INCLUDE A MINIMUM WARRANTY OF 1 YEAR OR 3000 HOURS.</p> <p>SPECIFY BRAND (& NUMBER IF APPLICABLE)</p> <p>COMMODITY CODE: 285-39-120826</p> <p>GENERATOR, TOWABLE, 250 KW, 60 HZ, DIESEL FUELED. SHALL HAVE ADJUSTABLE VOLTAGE TO INCLUDE AT LEAST 1-PHASE 120/240 AND 3-PHASE 240/480 VOLTS. SHALL INCLUDE A SOUND ATTENUATED ENCLOSURE. SHALL BE MOUNTED ON A TANDUM AXLE TRAILER. SHALL INCLUDE A TRAILER BREAKING SYSTEM. SHALL BE DOT APPROVED FOR HIGHWAY USE. SHOULD INCLUDE A 12/24 VOLT DC SYSTEM. SHALL INCLUDE A FUEL TANK CAPABLE OF SUPPORTING CONTINUOUS OPERATION AT 100% LOAD FOR AT LEAST 8 HOURS.</p> <p>TOWABLE GENERATOR SYSTEM SHALL INCLUDE A MINIMUM WARRANTY OF 1 YEAR OR 3000 HOURS.</p> <p>SPECIFY BRAND (& NUMBER IF APPLICABLE)</p>	1	EACH		